



168485

NZMN3-ME450-SVE

[Overview](#)[Specifications](#)[Resources](#)

## DELIVERY PROGRAM

[Delivery program](#)

Product range  
Circuit-breaker

[Technical data](#)

Protective function  
Motor protection

[Design verification as  
per IEC/EN 61439](#)[Technical data ETIM 7.0](#)

Standard/Approval  
IEC

[Dimensions](#)

Installation type  
Plug-in units

Release system  
Electronic release

Construction size  
NZMB

Description  
Tripping class 10 A  
IEC/EN 60947-4-1, IEC/EN 60947-2  
The circuit-breaker fulfills all requirements for AC-3 switching category.

Number of poles  
3 pole

Standard equipment  
Screw connection

Rated current = rated uninterrupted current [ $I_h = I_u$ ]  
450 A

### Setting range

Overload trip  
  
225 - 450 A

## TECHNICAL DATA

### General

Standards  
IEC/EN 60947

Protection against direct contact  
Finger and back of hand proof to VDE 0106 Part 100

Climatic proofing  
Damp heat, constant, to IEC 60068-2-78  
Damp heat, cyclic, to IEC 60068-2-30

Ambient temperature  
Ambient temperature, storage  
- 40 - + 70 °C

Ambient temperature  
Operation

-25 - +70 °C

Mechanical shock resistance (10 ms half-sinusoidal shock) according to IEC 60068-2-27  
20 (half-sinusoidal shock 20 ms) g


Safe isolation to EN 61140  
Between auxiliary contacts and main contacts  
500 V AC

Safe isolation to EN 61140  
between the auxiliary contacts  
300 V AC

Mounting position

Vertical and 90° in all directions

With XFI earth-fault release:



- NZM1, N1, NZM2, N2: vertical and 90° in all directions

with plug-in unit

- NZM1, N1, NZM2, N2: vertical, 90° right/left

with withdrawable unit:

- NZM3, N3: vertical, 90° right/left

- NZM4, N4: vertical

with remote operator:

- NZM2, N(S)2, NZM3, N(S)3, NZM4, N(S)4: vertical and 90° in all directions

Direction of incoming supply  
as required

Degree of protection

Device

In the operating controls area: IP20 (basic degree of protection)

Degree of protection

Enclosures

With insulating surround: IP40

With door coupling rotary handle: IP66

Degree of protection

Terminations

Tunnel terminal: IP10

Phase isolator and strip terminal: IP00

Other technical data (sheet catalogue)  
Temperature dependency, Derating

## Circuit-breakers

Rated current = rated uninterrupted current [ $I_h = I_u$ ]  
450 A

Rated surge voltage invariability [ $U_{imp}$ ]  
Main contacts  
8000 V

Rated surge voltage invariability [ $U_{imp}$ ]  
Auxiliary contacts  
6000 V

Rated operational voltage [ $U_e$ ]  
690 V AC

Overvoltage category/pollution degree  
III/3

Rated insulation voltage [ $U_i$ ]  
1000 V

Use in unearthed supply systems  
 690 V

## Switching capacity

Rated short-circuit making capacity [ $I_{cm}$ ]  
240 V [ $I_{cm}$ ]  
187 kA

Rated short-circuit making capacity [ $I_{cm}$ ]  
400/415 V [ $I_{cm}$ ]  
105 kA

Rated short-circuit making capacity [ $I_{cm}$ ]  
440 V 50/60 Hz [ $I_{cm}$ ]  
74 kA

Rated short-circuit making capacity [ $I_{cm}$ ]  
525 V 50/60 Hz [ $I_{cm}$ ]

53 kA

Rated short-circuit making capacity [ $I_{cm}$ ]  
690 V 50/60 Hz [ $I_c$ ]  
40 kA

Rated short-circuit breaking capacity  $I_{cn}$  [ $I_{cn}$ ]  
Ics to IEC/EN 60947 test cycle O-t-OO-t-OO [ $I_{cs}$ ]  
240 V 50/60 Hz [ $I_{cs}$ ]  
85 kA

Rated short-circuit breaking capacity  $I_{cn}$  [ $I_{cn}$ ]  
Ics to IEC/EN 60947 test cycle O-t-OO-t-OO [ $I_{cs}$ ]  
400/415 V 50/60 Hz [ $I_{cs}$ ]  
50 kA

Rated short-circuit breaking capacity  $I_{cn}$  [ $I_{cn}$ ]  
Ics to IEC/EN 60947 test cycle O-t-OO-t-OO [ $I_{cs}$ ]  
440 V 50/60 Hz [ $I_{cs}$ ]  
35 kA

Rated short-circuit breaking capacity  $I_{cn}$  [ $I_{cn}$ ]  
Ics to IEC/EN 60947 test cycle O-t-OO-t-OO [ $I_{cs}$ ]  
525 V 50/60 Hz [ $I_{cs}$ ]  
13 kA

Rated short-circuit breaking capacity  $I_{cn}$  [ $I_{cn}$ ]  
Ics to IEC/EN 60947 test cycle O-t-OO-t-OO [ $I_{cs}$ ]  
690 V 50/60 Hz [ $I_{cs}$ ]  
5 kA

Rated short-circuit breaking capacity  $I_{cn}$  [ $I_{cn}$ ]  
Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit-breaker.

Rated short-time withstand current  
 $t = 0.3$  s [ $I_{cw}$ ]  
3.3 kA

Rated short-time withstand current  
 $t = 1$  s [ $I_{cw}$ ]  
3.3 kA

Utilization category to IEC/EN 60947-2  
A

Lifespan, mechanical (of which max. 50 % trip by shunt/undervoltage release) [Operations]

15000

Lifespan, electrical  
AC-1  
400 V 50/60 Hz [Operations]  
5000

Lifespan, electrical  
AC-1  
415 V 50/60 Hz [Operations]  
5000

Lifespan, electrical  
AC-1  
690 V 50/60 Hz [Operations]  
3000

Lifespan, electrical  
AC-3  
400 V 50/60 Hz [Operations]  
2000

Lifespan, electrical  
AC-3  
415 V 50/60 Hz [Operations]  
2000

Lifespan, electrical  
AC-3  
690 V 50/60 Hz [Operations]  
2000

Lifespan, electrical  
Max. operating frequency  
60 Ops/h

Total break time at short-circuit  
< 10 ms

## Terminal capacity

Standard equipment  
Screw connection

Accessories required  
NZMB-XSVS

Optional accessories  
Box terminal  
Tunnel terminal  
connection on rear

Round copper conductor  
Box terminal  
Solid  
 $2 \times 16 \text{ mm}^2$

Round copper conductor  
Box terminal  
Stranded  
 $1 \times (35 - 240)$   
 $2 \times (25-120) \text{ mm}^2$

Round copper conductor  
Tunnel terminal  
Solid  
 $1 \times 16 \text{ mm}^2$

Round copper conductor  
Tunnel terminal  
Stranded  
1-hole  
 $1 \times (16 - 185) \text{ mm}^2$

Round copper conductor  
Bolt terminal and rear-side connection  
Direct on the switch  
Solid  
1 x 16  
 $2 \times 16 \text{ mm}^2$

Round copper conductor  
Bolt terminal and rear-side connection  
Direct on the switch  
Stranded  
 $1 \times (25 - 240)$   
 $2 \times (25 - 240) \text{ mm}^2$

Round copper conductor  
Bolt terminal and rear-side connection  
Connection width extension  
Connection width extension  
 $2 \times 300 \text{ mm}^2$

Al circular conductor  
Tunnel terminal  
Solid  
 $1 \times 16 \text{ mm}^2$

Al circular conductor  
Tunnel terminal  
Stranded  
Stranded  
 $1 \times (25 - 185)^2 \text{ mm}^2$

Al circular conductor  
Tunnel terminal  
Stranded  
Double hole  
 $1 \times (50 - 240)$   
 $2 \times (50 - 240) \text{ mm}^2$

Al circular conductor  
Tunnel terminal  
Stranded  
<sup>2)</sup> Up to 240 mm<sup>2</sup> can be connected depending on  
the cable manufacturer.

Cu strip (number of segments x width x segment  
thickness)  
Box terminal [min.]  
 $6 \times 16 \times 0.8 \text{ mm}$

Cu strip (number of segments x width x segment  
thickness)  
Box terminal [max.]  
 $10 \times 24 \times 1.0$   
 $+ 5 \times 24 \times 1.0$   
 $(2 \times) 8 \times 24 \times 1.0 \text{ mm}$

Cu strip (number of segments x width x segment  
thickness)  
Bolt terminal and rear-side connection  
Flat copper strip, with holes [min.]  
 $6 \times 16 \times 0.8 \text{ mm}$

Cu strip (number of segments x width x segment  
thickness)  
Bolt terminal and rear-side connection  
Flat copper strip, with holes [max.]  
 $10 \times 32 \times 1.0 + 5 \times 32 \times 1.0 \text{ mm}$

Cu strip (number of segments x width x segment  
thickness)  
Bolt terminal and rear-side connection  
Connection width extension  
 $(2 \times) 10 \times 50 \times 1.0 \text{ mm}$

Copper busbar (width x thickness) [mm]  
Bolt terminal and rear-side connection  
Screw connection

Copper busbar (width x thickness) [mm]  
Bolt terminal and rear-side connection  
Direct on the switch [min.]  
20 x 5 mm

Copper busbar (width x thickness) [mm]  
Bolt terminal and rear-side connection  
Direct on the switch [max.]  
30 x 10  
+ 30 x 5 mm

Copper busbar (width x thickness) [mm]  
Bolt terminal and rear-side connection  
Connection width extension  
Connection width extension [max.]  
2 x (10 x 50) mm

Control cables  
1 x (0.75 - 2.5)  
2 x (0.75 - 1.5) mm<sup>2</sup>

## DESIGN VERIFICATION AS PER IEC/EN 61439

### Technical data for design verification

Rated operational current for specified heat dissipation [ $I_h$ ]  
450 A

Equipment heat dissipation, current-dependent [ $P_{vid}$ ]  
60.75 W

Operating ambient temperature min.  
-25 °C

Operating ambient temperature max.  
+70 °C

### IEC/EN 61439 design verification

10.2 Strength of materials and parts

#### 10.2.2 Corrosion resistance

Meets the product standard's requirements.

#### 10.2 Strength of materials and parts

##### 10.2.3.1 Verification of thermal stability of enclosures

Meets the product standard's requirements.

#### 10.2 Strength of materials and parts

##### 10.2.3.2 Verification of resistance of insulating materials to normal heat

Meets the product standard's requirements.

#### 10.2 Strength of materials and parts

##### 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects

Meets the product standard's requirements.

#### 10.2 Strength of materials and parts

##### 10.2.4 Resistance to ultra-violet (UV) radiation

Meets the product standard's requirements.

#### 10.2 Strength of materials and parts

##### 10.2.5 Lifting

Does not apply, since the entire switchgear needs to be evaluated.

#### 10.2 Strength of materials and parts

##### 10.2.6 Mechanical impact

Does not apply, since the entire switchgear needs to be evaluated.

#### 10.2 Strength of materials and parts

##### 10.2.7 Inscriptions

Meets the product standard's requirements.

#### 10.3 Degree of protection of ASSEMBLIES

Does not apply, since the entire switchgear needs to be evaluated.

#### 10.4 Clearances and creepage distances

Meets the product standard's requirements.

#### 10.5 Protection against electric shock

Does not apply, since the entire switchgear needs to be evaluated.

#### 10.6 Incorporation of switching devices and

components

Does not apply, since the entire switchgear needs to be evaluated.

10.7 Internal electrical circuits and connections  
Is the panel builder's responsibility.

10.8 Connections for external conductors  
Is the panel builder's responsibility.

10.9 Insulation properties  
10.9.2 Power-frequency electric strength  
Is the panel builder's responsibility.

10.9 Insulation properties  
10.9.3 Impulse withstand voltage  
Is the panel builder's responsibility.

10.9 Insulation properties  
10.9.4 Testing of enclosures made of insulating material  
Is the panel builder's responsibility.

10.10 Temperature rise  
The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.

10.11 Short-circuit rating  
Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.12 Electromagnetic compatibility  
Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.13 Mechanical function  
The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

## TECHNICAL DATA ETIM 7.0

Overload release current setting  
225 - 450 A

Adjustment range undelayed short-circuit release  
900 - 5400 A

With thermal protection  
Yes

Phase failure sensitive  
Yes

Switch off technique  
Electronic

Rated operating voltage  
690 - 690 V

Rated permanent current  $I_p$   
450 A

Rated operation power at AC-3, 230 V  
132 kW

Rated operation power at AC-3, 400 V  
250 kW

Type of electrical connection of main circuit  
Screw connection

Type of control element  
Rocker lever

Device construction  
Built-in device plug-in technique

With integrated auxiliary switch  
No

With integrated under voltage release  
No

Number of poles  
3

Rated short-circuit breaking capacity Icu at 400 V,  
AC  
50 kA


Degree of protection (IP)  
IP20

Height  
215.2 mm

Width  
140 mm

Depth  
335 mm

## DIMENSIONS



- Blow out area, minimum clearance to adjacent parts
- Minimum clearance to adjacent parts





[Imprint](#) | [Privacy Policy](#) | [Legal Disclaimer](#) | [Terms and Conditions](#)  
©2022 by Eaton Industries GmbH