



113734
N2-200-SVE

Overview

Specifications

Resources



Delivery program

Technical data

Design verification as
per IEC/EN 61439

Technical data ETIM 7.0

Dimensions

DELIVERY PROGRAM

Product range
Switch-disconnectors

Protective function
Disconnectors/main switches

Standard/Approval
IEC

Installation type
Plug-in units

Construction size
N2

Description
Main switch characteristics including positive drive
to IEC/EN 60204 and VDE 0113.
Isolating characteristics to IEC/EN 60947-3 and
VDE 0660.
Busbar tag shroud to VDE 0160 Part 100.

Number of poles
3 pole

Switch positions
I, +, 0

Rated current = rated uninterrupted current [$I_n = I_u$]
200 A

Short-circuit protection max. fuse gL-
characteristic
250 A gL

TECHNICAL DATA

General

Standards
IEC/EN 60947

Protection against direct contact
Finger and back-of-hand proof to DIN EN
50274/VDE 0106 part 110

Climatic proofing
Damp heat, constant, to IEC 60068-2-78
Damp heat, cyclic, to IEC 60068-2-30

Ambient temperature
Ambient temperature, storage
- 40 - + 70 °C

Ambient temperature
Operation
-25 - +70 °C

Mechanical shock resistance (10 ms half-
sinusoidal shock) according to IEC 60068-2-27
20 (half-sinusoidal shock 20 ms) g


Safe isolation to EN 61140
Between auxiliary contacts and main contacts
500 V AC

Safe isolation to EN 61140
between the auxiliary contacts
300 V AC

Mounting position

Mounting position

Vertical and 90° in all directions



With residual-current release
XF:

- NZM1, N1, NZM2, N2: vertical
and 90° in all directions

with plug-in adapter elements

- NZM1, N1, NZM2, N2:
vertical, 90° right/left

with withdrawable unit:

- NZM3, N3: vertical, 90° left

- NZM4, N4: vertical

with remote operator:

- NZM2, N(S)2, NZM3, N(S)3,
NZM4, N(S)4: vertical and 90°
in all directions

Direction of incoming supply
as required

Degree of protection

Device

In the area of the HMI devices: IP20 (basic
protection type)

Degree of protection

Enclosures

With insulating surround: IP40

With door coupling rotary handle: IP66

Degree of protection

Terminations

Tunnel terminal: IP10

Phase isolator and band terminal: IP00

Switch-disconnectors

Rated surge voltage invariability [U_{imp}]

Main contacts

8000 V

Rated surge voltage invariability [U_{imp}]

Auxiliary contacts
6000 V

Rated operational voltage [U_e]
690 V AC

Rated operating frequency [f]
50/60 Hz

Rated current = rated uninterrupted current [$I_n = I_u$]
200 A

Overvoltage category/pollution degree
III/3

Rated insulation voltage [U_i]
690 V

Use in unearthed supply systems
☐ 690 V

Other technical data (sheet catalogue)
Weight
Temperature dependency, Derating
Effective power loss

Rated short-circuit making capacity [I_{cm}]

690 V 50/60 Hz [I_c]
5.5 kA

Rated short-time withstand current

$t = 0.3$ s [I_{cw}]
3.5 kA

$t = 1$ s [I_{cw}]
3.5 kA

The rated short-time withstand current for FN2/N2
in conjunction with earth-fault release NZM2-4-
XF... $I_{cw} = 1.5$ kA

Rated conditional short-circuit current [kA]

With back-up fuse
FN2(N2)-160...250: 250 A gG/gL

400 ... 415 V
100 kA

690 V
80 kA

With downstream fuse
FN2(N2)-160...250: 250 A gG/gL

400 ... 415 V
100 kA

690 V
80 kA

Rated making and breaking capacity

Rated operational current [I_e]
AC-22/23A
415 V [I_e]
200 A

Rated operational current [I_e]
AC-22/23A
690 V [I_e]
200 A

Lifespan, mechanical [Operations]
20000

Max. operating frequency
120 Ops/h

Lifespan, electrical

AC-1
400 V 50/60 Hz [Operations]
10000

AC-1

415 V 50/60 Hz [Operations]
10000

AC-1
690 V 50/60 Hz [Operations]
7500

AC-3
400 V 50/60 Hz [Operations]
7500

AC-3
415 V 50/60 Hz [Operations]
7500

AC-3
690 V 50/60 Hz [Operations]
5000

Terminal capacity

Accessories required
NZM2-XSVS socket base

Copper conductors and cables
Box terminal
Solid
1 x (10 - 16)
2 x (6 - 16) mm²

Copper conductors and cables
Box terminal
Stranded
1 x (25 - 185)
2 x (25 - 70) mm²

Copper conductors and cables
Tunnel terminal
Solid
1 x 16 mm²

Copper conductors and cables
Tunnel terminal
Stranded
1-hole
1 x (25 - 185) mm²

Copper conductors and cables
Bolt terminal and rear-side connection

Direct on the switch
Solid
1 x (10 - 16)
2 x (6 - 16) mm²

Copper conductors and cables
Bolt terminal and rear-side connection
Direct on the switch
Stranded
1 x (25 - 185)
2 x (25 - 70) mm²

Al conductors, Al cable
Tunnel terminal
Solid
1 x 16 mm²

Al conductors, Al cable
Tunnel terminal
Stranded
1-hole
1 x (25 - 185) mm²

Al conductors, Al cable
Bolt terminal and rear-side connection
Direct on the switch
Solid
1 x (10 - 16)
2 x (10 - 16) mm²

Al conductors, Al cable
Bolt terminal and rear-side connection
Direct on the switch
Stranded
1 x (25 - 185)
2 x (25 - 70) mm²

Cu strip (number of segments x width x segment thickness)
Box terminal [min.]
2 x 9 x 0.8 mm

Cu strip (number of segments x width x segment thickness)
Box terminal [max.]
10 x 16 x 0.8
(2x) 8 x 15.5 x 0.8 mm

Cu strip (number of segments x width x segment thickness)
Bolt terminal and rear-side connection
Flat copper strip, with holes [min.]
2 x 16 x 0.8 mm

Cu strip (number of segments x width x segment thickness)
Bolt terminal and rear-side connection
Flat copper strip, with holes [max.]
10 x 24 x 0.8 mm

Copper busbar (width x thickness) [mm]
Bolt terminal and rear-side connection
Screw connection
MB

Copper busbar (width x thickness) [mm]
Bolt terminal and rear-side connection
Direct on the switch [min.]
16 x 5 mm

Copper busbar (width x thickness) [mm]
Bolt terminal and rear-side connection
Direct on the switch [max.]
24 x 8 mm

DESIGN VERIFICATION AS PER IEC/EN 61439

Technical data for design verification

Rated operational current for specified heat dissipation [I_n]
200 A

Equipment heat dissipation, current-dependent [P_{vid}]
30.72 W

Operating ambient temperature min.
-25 °C

Operating ambient temperature max.
+70 °C

IEC/EN 61439 design verification

10.2 Strength of materials and parts
10.2.2 Corrosion resistance

Meets the product standard's requirements.

10.2 Strength of materials and parts

10.2.3.1 Verification of thermal stability of enclosures

Meets the product standard's requirements.

10.2 Strength of materials and parts

10.2.3.2 Verification of resistance of insulating materials to normal heat

Meets the product standard's requirements.

10.2 Strength of materials and parts

10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects

Meets the product standard's requirements.

10.2 Strength of materials and parts

10.2.4 Resistance to ultra-violet (UV) radiation

Meets the product standard's requirements.

10.2 Strength of materials and parts

10.2.5 Lifting

Does not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts

10.2.6 Mechanical impact

Does not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts

10.2.7 Inscriptions

Meets the product standard's requirements.

10.3 Degree of protection of ASSEMBLIES

Does not apply, since the entire switchgear needs to be evaluated.

10.4 Clearances and creepage distances

Meets the product standard's requirements.

10.5 Protection against electric shock

Does not apply, since the entire switchgear needs to be evaluated.

10.6 Incorporation of switching devices and components

Does not apply, since the entire switchgear needs to be evaluated.

10.7 Internal electrical circuits and connections
Is the panel builder's responsibility.

10.8 Connections for external conductors
Is the panel builder's responsibility.

10.9 Insulation properties
10.9.2 Power-frequency electric strength
Is the panel builder's responsibility.

10.9 Insulation properties
10.9.3 Impulse withstand voltage
Is the panel builder's responsibility.

10.9 Insulation properties
10.9.4 Testing of enclosures made of insulating material
Is the panel builder's responsibility.

10.10 Temperature rise
The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.

10.11 Short-circuit rating
Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.12 Electromagnetic compatibility
Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.13 Mechanical function
The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

TECHNICAL DATA ETIM 7.0

Low-voltage industrial components (EG000017) / Switch disconnecter (EC000216)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Off-load switch, circuit breaker, control switch / Switch disconnecter (ecl@ss10.0.1-27-37-14-03 [AKF060013])

Version as main switch

Yes

Version as maintenance-/service switch

Yes

Version as safety switch

No

Version as emergency stop installation

Yes

Version as reversing switch

No

Number of switches

1

Max. rated operation voltage U_e AC

690 V

Rated operating voltage

690 - 690 V

Rated permanent current I_u

200 A

Rated permanent current at AC-23, 400 V

0 A

Rated permanent current at AC-21, 400 V

0 A

Rated operation power at AC-3, 400 V

0 kW

Rated short-time withstand current I_{cw}

3.5 kA

Rated operation power at AC-23, 400 V
110 kW

Switching power at 400 V
0 kW

Conditioned rated short-circuit current I_q
0 kA

Number of poles
3

Number of auxiliary contacts as normally closed
contact
0

Number of auxiliary contacts as normally open
contact
0

Number of auxiliary contacts as change-over
contact
0

Motor drive optional
Yes

Motor drive integrated
No

Voltage release optional
Yes

Device construction
Built-in device plug-in technique

Suitable for ground mounting
Yes

Suitable for front mounting 4-hole
No

Suitable for front mounting centre
No

Suitable for distribution board installation
Yes

Suitable for intermediate mounting
Yes

Colour control element
Black

Type of control element
Rocker lever


Interlockable
Yes

Type of electrical connection of main circuit
Screw connection

Degree of protection (IP), front side
IP20

Degree of protection (NEMA)

DIMENSIONS



- ☐ Blow out area, minimum clearance to adjacent parts
- ☐ Minimum clearance to adjacent parts

