



113354

NZMH2-M20-SVE

[Overview](#)[Specifications](#)[Resources](#)

DELIVERY PROGRAM

[Delivery program](#)

Product range
Circuit-breaker

[Technical data](#)

Protective function
Motor protection

[Design verification as
per IEC/EN 61439](#)[Technical data ETIM 7.0](#)

Standard/Approval
IEC

[Characteristics](#)

Installation type
Plug-in units

[Dimensions](#)

Release system
Thermomagnetic release

Construction size
NZM2

Description

IEC/EN 60947-4-1, IEC/EN 60947-2

The circuit-breaker fulfills all requirements for AC-3 switching category.

R.m.s. value measurement and “thermal memory”

Adjustable time delay setting to overcome current peaks t_r at $6 \times I_r$ also infinity (without overload releases)

All AC-3 rating data applies to direct switching by the circuit-breaker under normal operating conditions. If, for example, a contactor takes over AC-3 switching under normal operating conditions, the full rated uninterrupted current applies to the circuit-breaker, $I_h = I_u$.

Number of poles

3 pole

Standard equipment

Screw connection

Switching capacity

400/415 V 50 Hz [I_{cu}]

150 kA

Rated current = rated uninterrupted current [$I_h = I_u$]

20 A

Setting range

Overload trip



16 - 20 A

Short-circuit releases

Non-delayed

350 A fixed

Motor rating AC-3 50/60 Hz [P]

380 V 400 V [P]

7.5 kW

Motor rating AC-3 50/60 Hz [P]

400 V [P]
7.5 kW

Rated operational current AC-3 50/60 Hz [I_e]

400 V [I_e]
16 A

TECHNICAL DATA

General

Standards
IEC/EN 60947

Protection against direct contact
Finger and back of hand proof to VDE 0106 Part
100

Climatic proofing
Damp heat, constant, to IEC 60068-2-78
Damp heat, cyclic, to IEC 60068-2-30

Ambient temperature
Ambient temperature, storage
- 40 - + 70 °C

Ambient temperature
Operation
-25 - +70 °C

Mechanical shock resistance (10 ms half-sinusoidal shock) according to IEC 60068-2-27
20 (half-sinusoidal shock 20 ms) g


Safe isolation to EN 61140
Between auxiliary contacts and main contacts
500 V AC

Safe isolation to EN 61140
between the auxiliary contacts
300 V AC

Mounting position

Vertical and 90° in all directions

With XFI earth-fault release:



- NZM1, N1, NZM2, N2: vertical and 90° in all directions
with plug-in unit

- NZM1, N1, NZM2, N2: vertical, 90° right/left

with withdrawable unit:

- NZM3, N3: vertical, 90° right/left

- NZM4, N4: vertical

with remote operator:

- NZM2, N(S)2, NZM3, N(S)3, NZM4, N(S)4: vertical and 90° in all directions

Direction of incoming supply as required

Degree of protection

Device

In the operating controls area: IP20 (basic degree of protection)

Degree of protection

Enclosures

With insulating surround: IP40

With door coupling rotary handle: IP66

Degree of protection

Terminations

Tunnel terminal: IP10

Phase isolator and strip terminal: IP00

Other technical data (sheet catalogue)

Temperature dependency, Derating

Circuit-breakers

Rated current = rated uninterrupted current [$I_h = I_u$]

20 A

Rated surge voltage invariability [U_{imp}]

Main contacts

8000 V

Rated surge voltage invariability [U_{imp}]

Auxiliary contacts

6000 V

Rated operational voltage [U_e]

690 V AC

Overvoltage category/pollution degree

III/3

Rated insulation voltage [U_i]

1000 V

Use in unearthing supply systems

690 V

Switching capacity

Rated short-circuit making capacity [I_{cm}]

240 V [I_{cm}]

330 kA

Rated short-circuit making capacity [I_{cm}]

400/415 V [I_{cm}]

330 kA

Rated short-circuit making capacity [I_{cm}]

440 V 50/60 Hz [I_{cm}]

286 kA

Rated short-circuit making capacity [I_{cm}]

525 V 50/60 Hz [I_{cm}]

105 kA

Rated short-circuit making capacity [I_{cm}]

690 V 50/60 Hz [I_{cm}]

40 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]

Icu to IEC/EN 60947 test cycle O-t-OO [I_{cu}]

240 V 50/60 Hz [I_{cu}]

150 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]

Icu to IEC/EN 60947 test cycle O-t-OO [I_{cu}]

400/415 V 50/60 Hz [I_{cu}]

150 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
Icu to IEC/EN 60947 test cycle O-t-OO [I_{cu}]
440 V 50/60 Hz [I_{cu}]
130 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
Icu to IEC/EN 60947 test cycle O-t-OO [I_{cu}]
525 V 50/60 Hz [I_{cu}]
50 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
Icu to IEC/EN 60947 test cycle O-t-OO [I_{cu}]
690 V 50/60 Hz [I_{cu}]
20 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
Ics to IEC/EN 60947 test cycle O-t-OO-t-OO [I_{cs}]
240 V 50/60 Hz [I_{cs}]
150 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
Ics to IEC/EN 60947 test cycle O-t-OO-t-OO [I_{cs}]
400/415 V 50/60 Hz [I_{cs}]
150 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
Ics to IEC/EN 60947 test cycle O-t-OO-t-OO [I_{cs}]
440 V 50/60 Hz [I_{cs}]
130 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
Ics to IEC/EN 60947 test cycle O-t-OO-t-OO [I_{cs}]
525 V 50/60 Hz [I_{cs}]
37.5 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
Ics to IEC/EN 60947 test cycle O-t-OO-t-OO [I_{cs}]
690 V 50/60 Hz [I_{cs}]
5 kA

Rated short-circuit breaking capacity I_{cn} [I_{cn}]
Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit-breaker.

Rated short-time withstand current
 $t = 0.3$ s [I_{cw}]
1.9 kA

Rated short-time withstand current
 $t = 1 \text{ s}$ [I_{cw}]
1.9 kA

Utilization category to IEC/EN 60947-2
A

Lifespan, mechanical (of which max. 50 % trip by shunt/undervoltage release) [Operations]
20000

Lifespan, electrical
AC-1
400 V 50/60 Hz [Operations]
10000

Lifespan, electrical
AC-1
415 V 50/60 Hz [Operations]
10000

Lifespan, electrical
AC-1
690 V 50/60 Hz [Operations]
7500

Lifespan, electrical
AC-3
400 V 50/60 Hz [Operations]
6500

Lifespan, electrical
AC-3
415 V 50/60 Hz [Operations]
6500

Lifespan, electrical
AC-3
690 V 50/60 Hz [Operations]
5000

Lifespan, electrical
Max. operating frequency
120 Ops/h

Total break time at short-circuit
< 10 ms

Terminal capacity

Standard equipment
Screw connection

Accessories required
NZM2-XSVS

Optional accessories
Box terminal
Tunnel terminal
connection on rear

Round copper conductor
Box terminal
Solid
1 x (10 - 16)
2 x (6 - 16) mm²

Round copper conductor
Box terminal
Stranded
1 x (25 - 185)
2 x (25 - 70) mm²

Round copper conductor
Tunnel terminal
Solid
1 x 16 mm²

Round copper conductor
Tunnel terminal
Stranded
1-hole
1 x (25 - 185) mm²

Round copper conductor
Bolt terminal and rear-side connection
Direct on the switch
Solid
1 x (10 - 16)
2 x (6 - 16) mm²

Round copper conductor
Bolt terminal and rear-side connection
Direct on the switch
Stranded
1 x (25 - 185)
2 x (25 - 70) mm²

Al circular conductor
Tunnel terminal
Solid
 $1 \times 16 \text{ mm}^2$

Al circular conductor
Tunnel terminal
Stranded
Stranded
 $1 \times (25 - 185) \text{ mm}^2$

Cu strip (number of segments x width x segment thickness)
Box terminal [min.]
 $2 \times 9 \times 0.8 \text{ mm}$

Cu strip (number of segments x width x segment thickness)
Box terminal [max.]
 $10 \times 16 \times 0.8$
(2x) $8 \times 15.5 \times 0.8 \text{ mm}$

Cu strip (number of segments x width x segment thickness)
Bolt terminal and rear-side connection
Flat copper strip, with holes [min.]
 $2 \times 16 \times 0.8 \text{ mm}$

Cu strip (number of segments x width x segment thickness)
Bolt terminal and rear-side connection
Flat copper strip, with holes [max.]
 $10 \times 24 \times 0.8 \text{ mm}$

Copper busbar (width x thickness) [mm]
Bolt terminal and rear-side connection
Screw connection
M8

Copper busbar (width x thickness) [mm]
Bolt terminal and rear-side connection
Direct on the switch [min.]
 $16 \times 5 \text{ mm}$

Copper busbar (width x thickness) [mm]
Bolt terminal and rear-side connection
Direct on the switch [max.]
 $24 \times 8 \text{ mm}$

Control cables
 $1 \times (0.75 - 2.5)$

2 x (0.75 - 1.5) mm²

DESIGN VERIFICATION AS PER IEC/EN 61439

Technical data for design verification

Rated operational current for specified heat dissipation [I_h]
20 A

Equipment heat dissipation, current-dependent [P_{vid}]
5.1 W

Operating ambient temperature min.
-25 °C

Operating ambient temperature max.
+70 °C

IEC/EN 61439 design verification

10.2 Strength of materials and parts
10.2.2 Corrosion resistance
Meets the product standard's requirements.

10.2 Strength of materials and parts
10.2.3.1 Verification of thermal stability of enclosures
Meets the product standard's requirements.

10.2 Strength of materials and parts
10.2.3.2 Verification of resistance of insulating materials to normal heat
Meets the product standard's requirements.

10.2 Strength of materials and parts
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects
Meets the product standard's requirements.

10.2 Strength of materials and parts
10.2.4 Resistance to ultra-violet (UV) radiation

Meets the product standard's requirements.

10.2 Strength of materials and parts

10.2.5 Lifting

Does not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts

10.2.6 Mechanical impact

Does not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts

10.2.7 Inscriptions

Meets the product standard's requirements.

10.3 Degree of protection of ASSEMBLIES

Does not apply, since the entire switchgear needs to be evaluated.

10.4 Clearances and creepage distances

Meets the product standard's requirements.

10.5 Protection against electric shock

Does not apply, since the entire switchgear needs to be evaluated.

10.6 Incorporation of switching devices and components

Does not apply, since the entire switchgear needs to be evaluated.

10.7 Internal electrical circuits and connections

Is the panel builder's responsibility.

10.8 Connections for external conductors

Is the panel builder's responsibility.

10.9 Insulation properties

10.9.2 Power-frequency electric strength

Is the panel builder's responsibility.

10.9 Insulation properties

10.9.3 Impulse withstand voltage

Is the panel builder's responsibility.

10.9 Insulation properties

10.9.4 Testing of enclosures made of insulating material
Is the panel builder's responsibility.

10.10 Temperature rise
The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.

10.11 Short-circuit rating
Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.12 Electromagnetic compatibility
Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.13 Mechanical function
The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

TECHNICAL DATA ETIM 7.0

Low-voltage industrial components (EG000017) / Motor protection circuit-breaker (EO000074)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Motor protection circuit-breaker (ecl@ss10.0.1-27-37-04-01 [AGZ529016])

Overload release current setting
16 - 20 A

Adjustment range undelayed short-circuit release
350 - 350 A

With thermal protection
Yes

Phase failure sensitive
No

Switch off technique

Thermomagnetic

Rated operating voltage
690 - 690 V

Rated permanent current I_u
20 A

Rated operation power at AC-3, 230 V
5.5 kW

Rated operation power at AC-3, 400 V
7.5 kW

Type of electrical connection of main circuit
Screw connection

Type of control element
Rocker lever

Device construction
Built-in device plug-in technique

With integrated auxiliary switch
No

With integrated under voltage release
No

Number of poles
3

Rated short-circuit breaking capacity I_{cu} at 400 V,
AC
150 kA

Degree of protection (IP)
IP20


Height
245 mm

Width
105 mm


Depth
180 mm

CHARACTERISTICS

Characteristic curve




Characteristic curve




Let-through current

Characteristic curve



Let-through energy

DIMENSIONS



- Blow out area, minimum clearance to adjacent parts
- Minimum clearance to adjacent parts

