

DECLARATION

Bochum / Germany, March 31st 2016

We declare that all Citel's surge protection devices have a built-in thermal-junction which will ensure a safe disconnect of the device in case of thermal runaway, in conformance with the EN 61643-11 regulations.

The conformance to EN 61643-11 has been tested and approved by an independent certification body (TUV) for the DS40 series of Type 2 SPDs.

This built-in thermal junction applies to both TN and IT network forms

Yours sincerely,

Alain Ruen
Director of Citel Gmbh

Alain Ruen

Telefax: 02 34/54 72 199

E-Mail: info@citel.de

Internet: www.citel.de

Director of Citel Gmbh