## **SIEMENS**

Data sheet 3UF7110-1AA01-0



Current/voltage measuring module V2; Set current  $0.3 \dots 4$  A, Voltage measurement up to 690 V, Overall width 45 mm, Straight-through transformer, basic unit required pro V PB, pro V MR, pro V PN or pro V EIP

product brand name	SIRIUS
product designation	Current/voltage measuring module
General technical data	
product function	
current measurement	Yes
<ul> <li>voltage measurement</li> </ul>	Yes
<ul> <li>active power measurement</li> </ul>	Yes
<ul> <li>power measurement</li> </ul>	Yes
<ul> <li>frequency measurement</li> </ul>	Yes
measuring procedure for current measurement	TRMS
current measuring range extension with external current transformers	Yes
measuring procedure for voltage measurement	TRMS
measurable supply voltage between the line conductors at AC maximum rated value	690 V
line conductors and neutral conductors internal resistance for voltage measurement	1 M $\Omega$ ; RC-based voltage divider
product component	
input for thermistor connection	No
consumed active power	0.5 W
insulation voltage	
<ul> <li>with degree of pollution 3 at AC rated value</li> </ul>	690 V
<ul> <li>for wires of main circuit according to IEC 60947-1 rated value</li> </ul>	6 kV
surge voltage resistance rated value	6 000 V
protection class IP	IP20
shock resistance according to IEC 60068-2-27	15g / 11 ms; with basic unit snapped on
vibration resistance	1-6 Hz / 15 mm; 6-500 Hz / 2 g; with basic unit snapped on: 1g
reference code according to IEC 81346-2	F
Substance Prohibitance (Date)	05/28/2009
certificate of suitability	
<ul> <li>according to ATEX directive 2014/34/EU</li> </ul>	BVS 06 ATEX F001
according to UKCA	ITS21UKEX0464
explosion device group and category according to ATEX directive 2014/34/EU	II (2) G, II (2 ) D, I (M2)
Electromagnetic compatibility	
EMC emitted interference according to IEC 60947-1	class A
EMC immunity according to IEC 60947-1	corresponds to degree of severity 3
conducted interference	
<ul> <li>due to burst according to IEC 61000-4-4</li> </ul>	2 kV
<ul> <li>due to conductor-earth surge according to IEC 61000-4-5</li> </ul>	2 kV
<ul> <li>due to conductor-conductor surge according to IEC</li> </ul>	1 kV

61000-4-5	
field-based interference according to IEC 61000-4-3	10 V/m
Inputs/ Outputs	TO VAIII
number of outputs as contact-affected switching element	0
Protective and monitoring functions	
product function	
power factor monitoring	Yes
-	Yes
ground-fault monitoring     walkage detection	Yes
voltage detection      trip class	CLASS 5E
trip class	OLAGO SE
product function	Yes
current detection     everload protection	Yes
overload protection  Precision	res
measuring precision	±/ 1.5 % 0.25 A
of frequency measurement      for current measurement 1.	+/- 1.5 %, 0.25 A 8 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos phi (0.51), 50/60 Hz, 25 °C
for current measurement 1	+/- 1.5 %, in range 0.25 A 8 A, in range 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), 50/60 Hz, 25 °C
for current measurement 2	+/- 3%, in range 8 A 32 A, in range 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), 50/60 Hz, 25 °C
for voltage measurement 1	+/- 1.5 %, in range 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), 50/60 Hz, 25 °C
at cos phi-measurement 1	+/- 1.5 %, 0.4 A 8 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos phi (0.51), 50/60 Hz, 25 °C
at cos phi-measurement 2	+/- 5%, 8 A 32 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos-phi (0.51), 50/60 Hz, 25 $^{\circ}\mathrm{C}$
at active power measurement 1	+/- 5 %, 0.25 8 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos phi (0.51), 50/60 Hz, 25 °C
at active power measurement 2	+/- 10%, 8 A 32 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos-phi (0.51), 50/60 Hz, 25 $^{\circ}\mathrm{C}$
at energy measurement 1	+/- 5 %, 0.25 8 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos phi (0.51), 50/60 Hz, 25 °C
at energy measurement 2	+/- 10%, 8 A 32 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos-phi (0.51), 50/60 Hz, 25 $^{\circ}\mathrm{C}$
at apparent power measurement 1	+/- 3%, 0.25 A 8 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos-phi (0.51), 50/60 Hz, 25 $^{\circ}\mathrm{C}$
at apparent power measurement 2	+/- 5 %, 8 A 32 A, 0.85 x 110 V 1.1 x 690 V (line-to-line voltages), cos phi (0.51), 50/60 Hz, 25 °C
accuracy of ground-fault monitoring	In the range 30 % 120 %/Is: +/- 10 % (Class CI-A), in range 15 % 30 % Ie: +/- 25 % (Class CI-B), both values acc. to IEC 60947-1 Annex T
temperature drift per °C	0.02 %/°C; Reference temperature: 25°C
measured variable frequency	45 65 Hz
Installation/ mounting/ dimensions	
mounting position	any
fastening method	screw and snap-on mounting
height	84 mm
width	45 mm
depth	64 mm
required spacing	
• top	30 mm
• bottom	30 mm
● left	0 mm
• right	0 mm
diameter of inlet opening	7.5 mm
diameter of inlet opening for current measurement	7.5 mm
Connections/ Terminals	
type of electrical connection at the measurement inputs for voltage	screw-type terminals
type of connectable conductor cross-sections at the measurement inputs for voltage	
finely stranded with core end processing	1x (0.25 2.5 mm²), 2x (0.25 1.0 mm²)
• solid	1x (0.25 2.5 mm²), 2x (0.25 1.0 mm²)
• for AWG cables solid	1x (24 14), 2x (24 18)
for AWG cables stranded	1x (20 14), 2x (20 16)
- IOI AVVO CADICO STIATIACA	11 (LV 17), LA (LV 10)

tightening torque at the measurement inputs for voltage	0.5 0.6 N·m		
tightening torque [lbf·in] at the measurement inputs for voltage	4.4 5.3 lbf-in		
mbient conditions			
installation altitude at height above sea level			
• 1 maximum	2 000 m		
• 2 maximum	3 000 m; max. +50 °C (no protective separation)		
• 3 maximum	4 000 m; max. +40 °C (no protective separation)		
ambient temperature			
<ul> <li>during operation</li> </ul>	-25 +60 °C		
during storage	-40 +80 °C		
during transport	-40 +80 °C		
environmental category			
during operation according to IEC 60721	3K6 (no formation of ice, no condensation, relative humidity 10 95%), 3C3 (no salt mist), 3S2 (sand must not get into the devices), 3M6		
<ul> <li>during storage according to IEC 60721</li> </ul>	1K6 (no condensation, relative humidity 10 $\dots$ 95%), 1C2 (no salt mist), 1S2 (sand must not get into the devices), 1M4		
<ul> <li>during transport according to IEC 60721</li> </ul>	2K2, 2C1, 2S1, 2M2		
relative humidity during operation	10 95 %		
hort-circuit protection			
product function short circuit protection	No		
alvanic isolation			
(electrically) protective separation according to IEC 60947-1	All circuits with protective separation (double creepage paths and clearances), the information in the "Protective Separation" test report, No. A0258, must be observed (link see further information)		
lain circuit			
number of poles for main current circuit	3		
adjustable current response value current of the current- dependent overload release	0.3 4 A		
operating voltage			
• at AC			
— at 50 Hz rated value	110 690 V		
— at 60 Hz rated value	110 690 V		
operating frequency rated value	50 60 Hz		
ontrol circuit/ Control			
type of voltage	AC		
inrush current maximum	40 A; 10 x lo		
Gertificates/ approvals			
General Product Approval		EMC	

(T)

Confirmation









For use in hazardous locations

Declaration of Conformity



IECEx







Explosion Protection Certificate



**Declaration of Conformity** 

**Test Certificates** 

Marine / Shipping



Type Test Certificates/Test Report

Special Test Certificate

Special Test Certificate





Marine / Shipping

other





## Confirmation PROFINET-Certification



Profibus

## Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3UF7110-1AA01-0

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3UF7110-1AA01-0

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)


https://support.industry.siemens.com/cs/ww/en/ps/3UF7110-1AA01-0


 $Image\ database\ (product\ images,\ 2D\ dimension\ drawings,\ 3D\ models,\ device\ circuit\ diagrams,\ EPLAN\ macros,\ ...)$ 


http://www.automation.siemens.com/bilddb/cax\_de.aspx?mlfb=3UF7110-1AA01-0&lang=en

Test report No. A0258, protective separation

https://support.industry.siemens.com/cs/ww/en/view/109748152







last modified: 8/16/2023 🖸