

2CMT2021-006202

To: Whom it May Concern

Subject: REACh Regulation for Contactors

Västerås, August 24th, 2023

With reference to the Regulation (EC) No 1907/2006 issued by the European Parliament and of the Council concerning the Registration, Evaluation, Authorization and Restriction of Chemicals (REACh) entered in force on 1st June 2007, please be informed that:

- ABB continuously assesses its products for content of Substances of Very High Concern (herein-after SVHC), included in the "Candidate List" by the European Chemicals Agency (ECHA) as per Annex XIV of the REACh Regulation
- under normal and reasonably foreseeable usage conditions, products manufactured by ABB do not intentionally release any substance or preparation
- a substance on its own, in a preparation or in an article, for which Annex XVII contains a restriction is not manufactured, placed on the market or used inside ABB products unless it complies with the conditions of that restriction.

According to the current best knowledge and according to the information provided by suppliers, ABB states that manufactured contactors, including block contactors, installation contactors, mini contactors, mini contactor relays, thermal overload relays, electronic overload relays and related accessories comply with the materials and the restrictions in Regulation (EC) No 1907/2006.

All information concerning SVHC listed in the "Candidate List" updated on January 17th, 2023 present in excess of 0.1% w/w is illustrated in appendix of document 2CMT2021-006202.

ABB Smart Power
Motor Starting & Safety
HUB Quality Manager, CEU

Régis Darnault



ABB Smart Power
Motor Starting & Safety
HUB R&D Manager, CEU

Charles Doiron



SVHC present in excess of 0.1% for Contactors

including block contactors, installation contactors, mini contactors, mini contactor relays, thermal overload relays, electronic overload relays and related accessories

Block contactors

Lead (CAS # 7439-92-1)

- Contactors AF/AFS09/12/16...(Z)(B)...30/40/22...10/01/11/22(K)/(RT)/(S)
- Contactors AF/AFS26/30/38...(Z)(B)...30/40/22...00/11/22(K)/(RT)/(S)
- Contactors AF/AFS40/52/65...30/40/22...00/11/22
- Contactors AF/AFS80/96...30/40/22...00/11/22
- Contactors AL...(Z)/TAL/9/12/16...30/40/22...10/01/22/32
- Contactors AL/TAL/26...30/40/22...10/01/32
- Contactors AL/TAL/30/40...30...10/01/32
- Contactors AF50/63/75...30...00/11/22
- Contactors AF45/50/75...40/22...00/11/22
- Contactors GA/GAE75...10...00/11
- Contactors UAF75...30...00...RA
- Contactor relays NF(Z)(B)22/31/40/44/53/62/71/80/33-11/51-11(K)/(RT)/(S)
- Contactor relays NL/NLZ/TNL/22/31/40/44/53/62/71/80/33-11/51-11
- Interface relays RA4, RA5-1
- Electronic timers TEF4(S), TE5S
- Damping device and pin in EK550..EK1000 and EHDB
- Surge suppressor, RC-EH800...RC-EH300
- Current Voltage Sensor SCV10
- Smart Function Module SFM1

Lead monoxide (lead oxide) (CAS # 1317-36-8)

- Current Voltage Sensor SCV10
- Smart Function Module SFM1

				Version D
Document Title	SVHC present in excess of 0.1% for Contactors	Document Number	2CMT2021-006202	Number of Pages
We reserve all rights related to this document and the data contained with prohibition to copy, to use or to disclose it to third parties in the absence of prior written permission issued by ABB S.p.A. © Copyright 2021 ABB. All rights reserved.		Place and Date of Issue	Västerås, 24 th august 2023	1