



Ref. Certif. No.

CN47858-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Motor Protection Circuit-breakers
Name and address of the applicant	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany
Name and address of the manufacturer	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany
Name and address of the factory	ABB Stotz-Kontakt GmbH Eppelheimer Strasse 82 69123 Heidelberg Germany
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	See the Appendix
Trademark (if any)	ABB
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	MS132, MO132
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016(5th Edition);IEC 60947-4-1:2018
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2018CQC-083988-1--M1,00901-CB2018CQC-083988-2--M2


This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: http://www.cqc.com.cn



Date: Sep.01,2020

Signature:   
Lu Mei

CB 0058646

MS132, MO132

Uimp: 6kV;

Ui: 690V;

Ue: AC230V,AC400V,AC440V,AC500V,AC690V;

In: 0.1-0.16A, 0.16-0.25A, 0.25-0.4A, 0.4-0.63A, 0.63-1.0A, 1.0-1.6A, 1.6-2.5A, 2.5-4.0A, 4.0-6.3A,6.3-10A, 8.0-12A, 10-16A,16-20A, 20-25A, 25-32A(except MS132-T);

Over current release type: Thermal magnetic;

Ics and Icu:

MS/MO132	MS132-T	230V		400V		440V		500V		690V	
		Ics	Icu	Ics	Icu	Ics	Icu	Ics	Icu	Ics	Icu
0,1-0,16 A	0,1-0,16 A	100kA	100kA	100kA	100kA	100kA	100kA	100kA	100kA	100kA	100kA
0,16-0,25 A	0,16-0,25 A										
0,25-0,4 A	0,25-0,4 A										
0,4-0,63 A	0,4-0,63 A										
0,63-1,0 A	0,63-1,0 A										
1,0-1,6 A	1,0-1,6 A										
1,6-2,5 A	1,6-2,5 A					20kA	20kA	20kA	3kA		
2,5-4,0 A	2,5-4,0 A										
4,0-6,3 A	4,0-6,3 A										
6,3-10,0 A	6,3-10,0 A										
8,0-12 A	8,0-12 A										
10-16 A	10-16 A										
16-20 A	16-20 A					50kA	50kA	10kA	10kA		
20-25 A	20-25 A										
25-32 A	--	25kA/50kA	25kA/50kA	10kA	10kA						

Page 1 of 2

Additional information (if necessary)

Date:

Sep.01,2020

Signature:



Lu Mei

Selectivity category: A; AC-3, AC-3e;

50/60Hz;

Suitability for isolation;

Trip Class: 10;

3P;

IP20(housing),

IP10(main circuit terminals);

Auxiliary contacts:

HKF1-xx, HKF1-xxK series

Ith:5A;

AC-15: Ue:/Ie: 24V/3A, 120V/3A, 240V/1.5A;

DC-13: Ue:/Ie: 24V/1A, 125V/0.27A, 250V/0.11A;

1NO1NC, 2NO;

HK1-xx, HK1-xxK, SK1-xx, SK1-xxK, CK1-xx series

Ith:6A;

AC-15: Ue:/Ie: 24V/6 A, 110-120V/6A, 220-240V/4A, 400V/3A, 690V/1A;

DC-13: Ue:/Ie: 24V/2A, 110-125V/0.55 A, 250V/0.27A, 400V/0.15A, 600V/0.15A;

1NO1NC, 2NO, 2NC

Page 2 of 2

Additional information (if necessary)

Date:

Sep.01,2020

Signature:



Lu Mei