



## Certificate of constancy of performance for smoke alarm device

In compliance with the Regulation 305/2011/UE of the European Parliament and of the Council of 9 March 2011 (Construction Products Regulation or CPR)

### Delivered by:

**Certification body:** AFNOR Certification  
**Identification number:** 0333  
**Address:** 11, rue Francis de Pressensé  
FR-93571 La Plaine Saint-Denis Cedex

### Issued to:

**Manufacturer:** HAGER SAFETY SAS  
**Address:** 364 rue Jean Monnet 38920 CROLLES FRANCE

**Manufacturing site:** GLD VILLARD BONNOT France

Description of the product: see Annex

AFNOR Certification attests that the provisions concerning the assessment and verification of constancy of performance and the performances described in annex ZA of the standard EN 14604 : 2005 + AC : 2008 under system 1 and that smoke alarm device fulfills the provisions described in annex ZA of the standard EN 14604 : 2005 + AC : 2008.

**Certificate number:** 0333-CPR-292074

Conditions and certificate validity period: this certificate was first issued on 06/03/2014.

Unless suspended or withdrawn, this certificate remains valid as long as the conditions laid down in the harmonized technical specifications or the manufacturing conditions in the factory or the factory production control itself are not significantly modified.

This certificate cancels and replaces any previous certificate

Date of issue of the certificate: 10/05/2023

Certificate expiry date : 30/01/2025



**Julien NIZRI**  
Managing Director of AFNOR Certification

**Annex to the certificate issued on 10/05/2023: 0333-CPR-292074**

Manufacturer: **HAGER SAFETY SAS**  
Address: **364 rue Jean Monnet 38920 CROLLES FRANCE**

Manufacturing site: **GLD VILLARD BONNOT France**

Product description:

Commercial reference	TG551A
Trade mark	HAGER
Type of mounting	Wall or ceiling
Main power supply	Internal power source
Battery name	CR17450E-R (FDK)
Battery duration	10 years
Connection of external ancillary devices	No
Individual alarm indicator	Yes
Interconnectable device	Yes
Suitable for installation in recreational vehicles	Yes
Alarm silence facility	Yes
File number	292.202301

This annex cannot be submitted or reproduced without the document to which it is attached.



**Julien NIZRI**  
Managing Director of AFNOR Certification