

# Eaton 132606

Catalog Number: 132606

Eaton Moeller® series M22 Illuminated selector switch actuator, RMQ-Titan, maintained, 2 positions, 1 NC, red, Blister pack for hanging

## General specifications

<b>Product Name</b>	<b>Catalog Number</b>
Eaton Moeller® series M22 Illuminated selector switch actuator	132606
	<b>Model Code</b>
	M22-WRLK-R-K01LED-BVP
<b>EAN</b>	<b>Product Length/Depth</b>
4015081295517	30 mm
<b>Product Height</b>	<b>Product Width</b>
210 mm	130 mm
<b>Product Weight</b>	<b>Compliances</b>
0.04 kg	CE

## Features & Functions

### Bezel color

Titanium

### Bezel material

Plastic

### Fitted with:

Front ring

## General

### Degree of protection

NEMA 4X

### Degree of protection (front side)

IP66

### Lifespan, mechanical

100,000 Operations

### Opening diameter

22.5 mm

### Overvoltage category

III

### Pollution degree

3

### Size

Front diameter: 29.7 mm

### Suitable for

Illumination

## Climatic environmental conditions

### Ambient operating temperature - min

-25 °C

### Ambient operating temperature - max

70 °C

## Actuator

### Actuator color

Black

### Actuator function

Switching function latching

### Actuator type

Toggle

### Number of switch positions

2

## Contacts

### Force for positive opening - min

0 N

## Design verification

### Equipment heat dissipation, current-dependent P<sub>vid</sub>

0 W

### Heat dissipation capacity P<sub>diss</sub>

0 W

### Heat dissipation per pole, current-dependent P<sub>vid</sub>

0 W

Rated operational current for specified heat dissipation (In)

0 A

Static heat dissipation, non-current-dependent Pvs

0 W

#### 10.2.2 Corrosion resistance

Meets the product standard's requirements.

##### 10.2.3.1 Verification of thermal stability of enclosures

Meets the product standard's requirements.

##### 10.2.3.2 Verification of resistance of insulating materials to normal heat

Meets the product standard's requirements.

##### 10.2.3.3 Resist. of insul. mat. to abnormal heat/fire by internal elect. effects

Meets the product standard's requirements.

#### 10.2.4 Resistance to ultra-violet (UV) radiation

Please enquire

#### 10.2.5 Lifting

Does not apply, since the entire switchgear needs to be evaluated.

#### 10.2.6 Mechanical impact

Does not apply, since the entire switchgear needs to be evaluated.

#### 10.2.7 Inscriptions

Meets the product standard's requirements.

#### 10.3 Degree of protection of assemblies

Does not apply, since the entire switchgear needs to be evaluated.

#### 10.4 Clearances and creepage distances

Meets the product standard's requirements.

#### 10.5 Protection against electric shock

Does not apply, since the entire switchgear needs to be evaluated.

#### 10.6 Incorporation of switching devices and components

Does not apply, since the entire switchgear needs to be evaluated.

#### 10.7 Internal electrical circuits and connections

Is the panel builder's responsibility.

#### 10.8 Connections for external conductors

Is the panel builder's responsibility.

## Resources

### Brochures

#### Catalogues

[eaton-rmq-titan-brochure-br047004en-en-us.pdf](#)

[Flip catalog - Product Range Catalog - Command and indication](#)

[eaton-pushbuttons-signal-towers-sensors-assortment-overview-catalog-ca047003en-en-us.pdf](#)

#### Certification reports

[0000SPC-179](#)

[0000SPC-183](#)

#### Declarations of conformity

[DA-DC-00004157.pdf](#)

[DA-DC-00004135.pdf](#)

#### Drawings

[eaton-general-approval-m22-symbol.eps](#)

[eaton-general-m22-standards.eps](#)

[eaton-general-m22-symbol.eps](#)

[0000SPC-180](#)

#### Installation instructions

[IL04716002Z](#)

#### Installation videos

[RMQ Flat Design](#)

#### mCAD model

[eaton-cadenas-path-temp-assemblies-bg\\_wk\\_1led0\\_asmtpl.prj](#)

[DA-CS-bg\\_wk\\_1led0](#)

[eaton-cadenas-side\\_view-bg\\_wk\\_1led0\\_side.pra](#)

[DA-CD-bg\\_wk\\_1led0](#)

[eaton-cadenas-front\\_view-bg\\_wk\\_1led0\\_front.pra](#)

[eaton-cadenas-rear\\_view-bg\\_wk\\_1led0\\_back\\_rear.pra](#)

#### Multimedia

[RMQ small E-Stop emergency-stop button](#)

[MCI MultiColor Light Indicator RMQ compact solution](#)

[MCI Multicolor Light Indicator M22 with SmartWire-DT](#)

[easyE4 SmartWire-DT module with Remote Touch Display and RMQ multi color indicator](#)

#### Sales notes

[eaton-rmq-flat-enclosure-flyer-fl047003en-en-us.pdf](#)

### 10.9.2 Power-frequency electric strength

Is the panel builder's responsibility.

### 10.9.3 Impulse withstand voltage

Is the panel builder's responsibility.

### 10.9.4 Testing of enclosures made of insulating material

Is the panel builder's responsibility.

### 10.10 Temperature rise

Not applicable.

### 10.11 Short-circuit rating

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

### 10.12 Electromagnetic compatibility

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

### 10.13 Mechanical function

The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

[eaton-control circuit-devices rmq-titan-fl144090en-en-us.pdf](#)

[eaton-rmq-mci-multi-color-light-indicator-flyer-fl047005en-en-us.pdf](#)

[eaton-rmq-small-e-stop-flyer-fl047006en-en-us.pdf](#)

[System overview](#)

[Pilot devices - selection aid](#)



Eaton Corporation plc  
Eaton House  
30 Pembroke Road  
Dublin 4, Ireland  
Eaton.com

© 2025 Eaton. All rights reserved.

Eaton is a registered trademark.

All other trademarks are property of their respective owners.



[Eaton.com/socialmedia](https://Eaton.com/socialmedia)