


# FDV - DIODE klemme, Skruklemme, WK, 4E/U-URL -VO

EFA-varenr.:	121000507
EI-nummer:	1264725
Leverandørens varenr.	57.404.8355.5
Type betegnelse:	WK 4 E / U G-URL/VO
GTIN-nr.:	4015573604711
Leverandør:	Wieland Electric GmbH
Sertifikat:	
Etim-klasse:	EC000903 - Komponent-rekkelemme
Tolltariff:	85369010
Salgsenhet:	Stk
Blokk nr.:	100101



## Beskrivelse

Fler-etasjers funksjonsklemme med skruetilkopling for montering på TS 35 og TS 32, nominelt tverrsnitt 4 mm<sup>2</sup>, bredde 6 mm, farge rød

## Teknisk beskrivelse

SELOS Screw connection with rising cage clamp 0.5 to 150 mm<sup>2</sup> Standard DIN rail terminal blocks Duo DIN rail terminal blocks Multi-tier blocks Initiator/actuator blocks Measuring/disconnect blocks Fuse blocks Function blocks DIN rail terminal blocks with pluggable connection Miniature terminal blocks DIN rail terminal blocks for junction boxes High current blocks selos according to US standard UL 94 V-0 Elastic clamping body Rated cross section: 2.5 to 150 mm<sup>2</sup> Connection range: 0.5 to 185 mm<sup>2</sup> Universal foot All Wieland Components which require CE general certification are CE certified, and identified with the CE logo Technical information The information regarding cross sectional area and connection types pertains to unprepared wires without ferrules. The voltage ratings apply to the terminals in their intended application. When different products are mounted adjacent to each other, the proper isolation distances must be adhered to. If the ground blocks of the taris product family are not used in block assemblies, but are mounted to the rail as single terminal blocks, end clamps have to be used. A detailed description of technical data, the standards requirements, and the application conditions are available under facts & DATA. ATEX regulation For the use of DIN rail terminal blocks in Ex areas, the regulations of EN 50014 apply, whereas for increased safety EExe the regulations of EN 50019 must be followed. For an approximation of the laws of the EU member states, directive 94/9/EG was created, which is generally known as ATEX 100a and which is the basis for harmonization in this field. ATEX stands for 'atmosphere explosive' while 100a refers to the corresponding article of the EC contract. Directive ATEX 100a applies for protection against dust and gas explosions in all industrial Ex areas and in mining. The testing and certificating institutes named in directive ATEX100a must follow accreditation procedures which are the same all over Europe. In accordance with EN 50014/50019 and ATEX 100a, these certificating institutes write out EC certificates for prototype tests. These prototype test certificates for components together with the corresponding quality system certification of the supplier are required to obtain the so-called ATEX approval. In combination with the Ex mark, the markings of the Wieland terminal blocks have the following meaning: Ex Identification II Device group 2 Category

## ETIM-egenskaper

Tilkoblingsbart ledertverrsnitt fintrådet	0,5 - 4
Tilkoblingsbart ledertverrsnitt entrådet	0,5 - 4
Merkestrøm In	1
Merkespenning	400



Tilkoblingstype 1	Skrukobling
Tilkoblingstype 2	Skrukobling
Antall etasjer	2
Antall klemmeposisjoner per nivå	2
Internt koblede trinn	Nei
Monteringsmetode	DIN-/G-skinne TH35/G32
Materiale i isolasjonskropp	Termoplast
Driftstemperaturområde	-40 - 55
Terminalplate nødvendig	Ja
Farge	Rød
Type komponent	Diode

## Retur/Deponi

Produktet skal leveres til godkjent avfallsdeponi.