Specifications



Photo is representative

Eaton 189628

NZMH4-PX1000-AVE. NZM4 PXR25 circuit breaker - integrated energy measurement class 1, 1000A, 3p, Screw terminal, withdrawable unit

| General specification | ns |
|-------------------------|---|
| PRODUCT NAME | Eaton Moeller series NZM molded case circuit breaker electronic |
| CATALOG NUMBER | 189628 |
| MODEL CODE | NZMH4-PX1000-AVE |
| EAN | 4015081875757 |
| PRODUCT LENGTH/DEPTH | 501 mm |
| PRODUCT HEIGHT | 280 mm |
| PRODUCT WIDTH | 260 mm |
| PRODUCT WEIGHT | 29 kg |
| COMPLIANCES | RoHS conform |
| CERTIFICATIONS | IEC IEC/EN 60947 |
| GLOBAL CATALOG | 189628 |



| Product specifications | 5 | F | ₹6 |
|--|--|---|----|
| AMPERAGE RATING | 1000 A | | |
| VOLTAGE RATING | 690 V - 690 V | | |
| CIRCUIT BREAKER FRAME TYPE | NZM4 | В | 3R |
| FEATURES | Protection unit Motor drive optional | | |
| ACCESSORIES REQUIRED | NZM4-XAVS | C | CΑ |
| 10.10 TEMPERATURE RISE | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. | | DE |
| 10.11 SHORT-CIRCUIT RATING | Is the panel builder's responsibility. The specifications for the switchgear must be observed. | E |)F |
| 10.12 ELECTROMAGNETIC COMPATIBILITY | Is the panel builder's responsibility. The specifications for the switchgear must be | | N: |
| 10.13 MECHANICAL FUNCTION | observed. The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. | | N: |
| 10.2.2 CORROSION RESISTANCE | Meets the product standard's requirements. | P | PE |
| 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES | Meets the product standard's requirements. | т | ΓЕ |
| 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT | Meets the product standard's requirements. | _ | |
| 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS | Meets the product standard's requirements. | | |
| 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION | Meets the product standard's requirements. | | |
| 10.2.5 LIFTING | Does not apply, since the entire switchgear needs to be evaluated. | | |
| 10.2.6 MECHANICAL | Does not apply, since the entire switchgear needs to | | |

| Resources | |
|-------------------------------|--|
| BROCHURES | eaton-digital-nzm- brochure-br013003en-en- us.pdf |
| | eaton-feerum-the-whole- grain-solution-success- story-en-us.pdf |
| CATALOGS | eaton-digital-nzm-catalog- ca013003en-en-us.pdf |
| DECLARATIONS OF CONFORMITY | eaton-molded-case-circuit- breaker-declaration-of- conformity- eu250294en.pdf |
| DRAWINGS | eaton-circuit-breaker-nzm- mccb-dimensions-022.eps |
| | eaton-circuit-breaker- withdrawable-unit-nzm- mccb-dimensions.eps |
| INSTALLATION INSTRUCTIONS | eaton-circuit-breaker- basic-unit-bg4- il012101zu.pdf |
| INSTALLATION VIDEOS | Introduction of the new digital circuit breaker NZM |
| | The new digital NZM Range |
| MCAD MODEL | DA-CD-nzm4_3p |
| | DA-CS-nzm4 3p |
| PEP ECO-PASSPORT | eaton-molded-case- switches-pep-eato-00243- v0101-en.pdf |
| TECHNICAL DATA SHEETS | eaton-nzm-technical- information-sheet |

| 10.2.7 INSCRIPTIONS | Meets the product standard's requirements. |
|--|--|
| 10.3 DEGREE OF PROTECTION OF ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 CLEARANCES AND CREEPAGE DISTANCES | Meets the product standard's requirements. |
| 10.5 PROTECTION AGAINST ELECTRIC SHOCK | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS | ls the panel builder's responsibility. |
| 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS | ls the panel builder's responsibility. |
| 10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH | ls the panel builder's responsibility. |
| 10.9.3 IMPULSE WITHSTAND VOLTAGE | ls the panel builder's responsibility. |
| 10.9.4 TESTING OF ENCLOSURES MADE OF | Is the panel builder's |
| INSULATING MATERIAL | responsibility. |
| | responsibility. |
| INSULATING MATERIAL | · · |
| INSULATING MATERIAL POLLUTION DEGREE | 3 Withdrawable Built-in device slide-in |
| POLLUTION DEGREE MOUNTING METHOD | Withdrawable Built-in device slide-in technique (withdrawable) Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC |
| INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- | Withdrawable Built-in device slide-in technique (withdrawable) Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 |
| INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT | Withdrawable Built-in device slide-in technique (withdrawable) Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 |
| INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY | Withdrawable Built-in device slide-in technique (withdrawable) Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 123 W B (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the |
| INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY ISOLATION AMBIENT OPERATING | Withdrawable Built-in device slide-in technique (withdrawable) Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 123 W B (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) |
| INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY ISOLATION AMBIENT OPERATING TEMPERATURE - MAX AMBIENT OPERATING | Withdrawable Built-in device slide-in technique (withdrawable) Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 123 W B (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) 70 °C |

| NUMBER OF AUXILIARY CONTACTS (CHANGE-OVER CONTACTS) | 0 |
|---|--|
| NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS) | 0 |
| NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS) | 0 |
| PROTECTION AGAINST DIRECT CONTACT | Finger and back-of-hand proof to VDE 0106 part 100 |
| DEGREE OF PROTECTION | IP20 IP20 (basic degree of protection, in the operating controls area) |
| DIRECTION OF INCOMING SUPPLY | As required |
| ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT | Other |
| LIFESPAN, MECHANICAL | 10000 operations |
| OVERVOLTAGE CATEGORY | III |
| DEGREE OF PROTECTION (IP), FRONT SIDE | IP40 (with insulating surround) IP66 (with door coupling rotary handle) |
| DEGREE OF PROTECTION (TERMINATIONS) | IP10 (tunnel terminal) IP00 (terminations, phase isolator and strip terminal) |
| NUMBER OF POLES | Three-pole |
| TERMINAL CAPACITY (COPPER STRIP) | Min. 5 segments of 25 mm x 1 mm at rear-side connection (punched) Max. 10 segments of 32 mm x 1 mm (2x) at flat conductor terminal Min. 10 segments of 50 mm x 1 mm (2x) at rear-side connection (punched) 10 segments of 80 mm x 1 mm (2x) at rear-side width extension Min. 6 segments of 16 mm x 0.8 mm at flat conductor terminal 10 segments of 50 mm x 1 mm (2x) at 1-hole module |
| LIFESPAN, ELECTRICAL | 3000 operations at 415 V AC-1 |
| | 3000 operations at 400 V |

| | AC-1 2000 operations at 690 V AC-1 |
|------------------|--|
| FUNCTIONS | Systems, cable, selectivity and generator protection |
| ТҮРЕ | Circuit breaker |
| SPECIAL FEATURES | LSI overload protection and delayed and non-delayed short-circuit protective device Class 1 energy measurement, r.m.s. value measurement, and "thermal memory" USB interface for configuration and test function with Power Xpert Protection Manager software Interface module in equipment supplied. Optionally communication-capable with internal Modbus RTU module or CAM Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit breaking capacity lcn) Rated current = rated uninterrupted current: 1000 A |
| APPLICATION | 525 V |
| SHOCK RESISTANCE | 15 g (half-sinusoidal shock 11 ms) |

| 525 V |
|---------------------------------------|
| 15 g (half-sinusoidal shock 11 ms) |
| Connection at separate chassis part |
| 1000 A |
| |

| DELEACE CYCTEL | Flacture in the second |
|--|--|
| RELEASE SYSTEM | Electronic release |
| SHORT-CIRCUIT TOTAL BREAKTIME | < 25 ms (415 V); < 35 ms (> 415 V) |
| RATED SHORT-TIME WITHSTAND CURRENT (T = 0.3 S) | 19.2 kA |
| RATED SHORT-TIME WITHSTAND CURRENT (T = 1 S) | 19.2 kA |
| SHORT-CIRCUIT RELEASE DELAYED SETTING - MAX | 10 A |
| SHORT-CIRCUIT RELEASE DELAYED SETTING - MIN | 2 A |
| SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MAX | 18 A |
| SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MIN | 2 A |
| TERMINAL CAPACITY (CONTROL CABLE) | 0.75 mm ² - 2.5 mm ² (1x) 0.75 mm ² - 1.5 mm ² (2x) |
| TERMINAL CAPACITY (COPPER BUSBAR) | M10 at rear-side screw connection Max. 80 mm x 10 mm (2x) at rear-side width extension Min. 25 mm x 5 mm direct at switch rear-side connection Max. 50 mm x 10 mm (2x) direct at switch rear-side connection Min. 25 mm x 5 mm at rear-side 1-hole module plate Min. 60 mm x 10 mm at rear-side width extension Max. 50 mm x 10 mm (2x) at rear-side 1-hole module plate 50 mm x 10 mm (2x) at rear-side 2-hole module plate |
| TERMINAL CAPACITY (COPPER SOLID CONDUCTOR/CABLE) | 120 mm ² - 300 mm ² (1x) at rear-side 1-hole module plate 35 mm ² - 185 mm ² (4x) at rear-side 2-hole module plate 50 mm ² - 240 mm ² (4x) at 4-hole tunnel terminal 300 mm ² (4x) at rear-side width extension |

| | 95 mm ² - 185 mm ² (2x) at rear-side 2-hole module plate 95 mm ² - 300 mm ² (2x) at rear-side 1-hole module plate 95 mm ² - 240 mm ² (6x) at rear-side width extension |
|--|---|
| TERMINAL CAPACITY (COPPER STRANDED CONDUCTOR/CABLE) | 120 mm ² - 185 mm ² (1x) direct at switch rear-side connection 50 mm ² - 185 mm ² (4x) direct at switch rear-side connection |
| TERMINAL CAPACITY (ALUMINUM STRANDED CONDUCTOR/CABLE) | 50 mm² - 240 mm² (4x) at 4-hole tunnel terminal |
| HANDLE TYPE | Rocker lever |
| SHORT DELAY CURRENT SETTING (ISD) - MAX | 10 A |
| SHORT DELAY CURRENT SETTING (ISD) - MIN | 2 A |
| INSTANTANEOUS CURRENT SETTING (II) - MAX | 18 A |
| INSTANTANEOUS CURRENT SETTING (II) - MIN | 2 A |
| NUMBER OF OPERATIONS PER HOUR - MAX | 60 |
| OVERLOAD CURRENT SETTING (IR) - MAX | 1000 A |
| OVERLOAD CURRENT SETTING (IR) - MIN | 500 A |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 230 V, 50/60 HZ | 63 kA |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 400/415 V, 50/60 HZ | 50 kA |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 440 V, 50/60 HZ | 50 kA |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 525 V, 50/60 HZ | 37 kA |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 690 V, | 37 kA |

| 50/60 HZ | |
|---|---|
| RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 400/415 V, 50/60 HZ | 187 kA |
| RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 440 V, 50/60 HZ | 187 kA |
| RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 525 V, 50/60 HZ | 143 kA |
| RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 690 V, 50/60 HZ | 100 kA |
| STANDARD TERMINALS | Screw connection |
| | |
| OPTIONAL TERMINALS | Connection on rear. Strip terminal. Tunnel terminal |
| OPTIONAL TERMINALS RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 240 V, 50/60 HZ | |
| RATED SHORT-CIRCUIT MAKING CAPACITY ICM | terminal. Tunnel terminal |
| RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 240 V, 50/60 HZ RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT AUXILIARY | terminal. Tunnel terminal 275 kA |

| PROJECT NAME: | |
|-----------------|--|
| PROJECT NUMBER: | |
| PREPARED BY: | |
| DATE: | |



Eaton Corporation plc Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

 $\hbox{@ 2025 Eaton.}$ All Rights Reserved.

Follow us on social media to get the latest product and support information.









