# Specifications



### Photo is representative





## Eaton 191618

Eaton Moeller series NZM - Molded Case Circuit Breaker. NZM3 PXR20 circuit breaker, 400A, 4p, earth-fault protection, withdrawable unit, N, 3

General specifications	
PRODUCT NAME	Eaton Moeller series NZM molded case circuit breaker electronic
CATALOG NUMBER	191618
MODEL CODE	NZMN3-4-VX400-T-AVE
EAN	4015081921300
PRODUCT LENGTH/DEPTH	260 mm
PRODUCT HEIGHT	346 mm
PRODUCT WIDTH	230 mm
PRODUCT WEIGHT	22.989 kg
COMPLIANCES	RoHS conform
CERTIFICATIONS	IEC/EN 60947 IEC
GLOBAL CATALOG	191618



Product specifications	
AMPERAGE RATING	400 A
VOLTAGE RATING	690 V - 690 V
CIRCUIT BREAKER FRAME TYPE	NZM3
FEATURES	Protection unit Motor drive optional
ACCESSORIES REQUIRED	NZM3-4-XAVS
10.10 TEMPERATURE RISE	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Meets the product standard's requirements.
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.

Resources	
BROCHURES	eaton-feerum-the-whole- grain-solution-success- story-en-us.pdf
	eaton-digital-nzm- brochure-br013003en-en- us.pdf
CATALOGS	eaton-digital-nzm-catalog- ca013003en-en-us.pdf
CHARACTERISTIC CURVE	eaton-circuit-breaker-nzm- mccb-characteristic-curve- 011.eps
	eaton-circuit-breaker-nzm- mccb-characteristic-curve- 015.eps
DECLARATIONS OF CONFORMITY	eaton-molded-case-circuit- breaker-declaration-of- conformity- eu250293en.pdf
DRAWINGS	eaton-circuit-breaker- switch-nzm-mccb- dimensions-016.eps
	eaton-circuit-breaker-nzm- mccb-dimensions-021.eps
INSTALLATION INSTRUCTIONS	eaton-circuit-breaker- basic-unit-bg3- il012100zu.pdf
INSTALLATION VIDEOS	The new digital NZM Range
	Introduction of the new digital circuit breaker NZM
MCAD MODEL	DA-CD-nzm3 4 xave
PEP ECO-PASSPORT	eaton-molded-case- switches-pep-eato-00252- v0101-en.pdf
TECHNICAL DATA SHEETS	eaton-nzm-technical- information-sheet

10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	ls the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	ls the panel builder's responsibility.
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	ls the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	ls the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF	ls the panel builder's
INSULATING MATERIAL	responsibility.
	-
INSULATING MATERIAL	responsibility.
INSULATING MATERIAL POLLUTION DEGREE	responsibility.  3  Withdrawable Built-in device slide-in
POLLUTION DEGREE  MOUNTING METHOD	responsibility.  3  Withdrawable Built-in device slide-in technique (withdrawable)  Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to
INSULATING MATERIAL  POLLUTION DEGREE  MOUNTING METHOD  CLIMATIC PROOFING  EQUIPMENT HEAT DISSIPATION, CURRENT-	responsibility.  3 Withdrawable Built-in device slide-in technique (withdrawable)  Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78
INSULATING MATERIAL  POLLUTION DEGREE  MOUNTING METHOD  CLIMATIC PROOFING  EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT	responsibility.  3 Withdrawable Built-in device slide-in technique (withdrawable)  Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78
INSULATING MATERIAL  POLLUTION DEGREE  MOUNTING METHOD  CLIMATIC PROOFING  EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT  UTILIZATION CATEGORY	responsibility.  3 Withdrawable Built-in device slide-in technique (withdrawable)  Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78  72 W  A (IEC/EN 60947-2)  500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the
INSULATING MATERIAL  POLLUTION DEGREE  MOUNTING METHOD  CLIMATIC PROOFING  EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT  UTILIZATION CATEGORY  ISOLATION  AMBIENT OPERATING	responsibility.  3 Withdrawable Built-in device slide-in technique (withdrawable)  Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78  72 W  A (IEC/EN 60947-2)  500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts)
INSULATING MATERIAL  POLLUTION DEGREE  MOUNTING METHOD  CLIMATIC PROOFING  EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT  UTILIZATION CATEGORY  ISOLATION  AMBIENT OPERATING TEMPERATURE - MAX  AMBIENT OPERATING	responsibility.  3 Withdrawable Built-in device slide-in technique (withdrawable)  Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78  72 W  A (IEC/EN 60947-2)  500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts)  70 °C

NUMBER OF AUXILIARY CONTACTS (CHANGE- OVER CONTACTS)	0
NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)	0
NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)	0
PROTECTION AGAINST DIRECT CONTACT	Finger and back-of-hand proof to DIN EN 50274/VDE 0106 part 110
DEGREE OF PROTECTION	IP20 IP20 (basic degree of protection, in the operating controls area)
DIRECTION OF INCOMING SUPPLY	As required
ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT	Other
CURRENT RATING OF NEUTRAL CONDUCTOR	200% of phase conductor
LIFESPAN, MECHANICAL	15000 operations
OVERVOLTAGE CATEGORY	III
DEGREE OF PROTECTION (IP), FRONT SIDE	IP40 (with insulating surround) IP66 (with door coupling rotary handle)
DEGREE OF PROTECTION (TERMINATIONS)	IP10 (tunnel terminal) IP00 (terminations, phase isolator and strip terminal)
NUMBER OF POLES	Four-pole
	Max. 10 segments of 32 mm x 1 mm + 5 segments of 32 mm x 1 mm at rear- side connection (punched) Max. 10 segments of 24
TERMINAL CAPACITY (COPPER STRIP)	mm x 1 mm + 5 segments of 24 mm x 1 mm Min. 6 segments of 16 mm x 0.8 mm at box terminal Max. 8 segments of 24 mm x 1 mm (2x) at box terminal
	10 segments of 50 mm x 1 mm (2x) at rear-side width extension Min. 6 segments of 16 mm
	x 0.8 mm at rear-side connection (punched)

	AC-1 3000 operations at 690 V AC-1 5000 operations at 415 V AC-1
FUNCTIONS	Systems, cable, selectivity and generator protection Earth-fault protection Integrated earth fault protection
EARTH-FAULT CURRENT SETTING (IG) - MAX	400 x In
ТҮРЕ	Circuit breaker

- LSI overload protection and delayed and nondelayed shortcircuit protective device
- R.m.s. value measurement and "thermal memory"
- USB interface for configuration and test function with Power Xpert Protection Manager software
- Optionally communicationcapable with interface module and internal Modbus RTU module or CAM
- Maximum back-up fuse, if the expected shortcircuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit breaking capacity lcn)
- Rated current = rated uninterrupted current: 400 A
- Terminal capacity hint: Up to 240 mm² can be connected depending on the cable

### **SPECIAL FEATURES**

### manufacturer.

APPLICATION	Use in unearthed supply systems at 690 V	
SHOCK RESISTANCE	20 g (half-sinusoidal shock 20 ms)	
EARTH-FAULT CURRENT SETTING (IG) - MIN	80 x ln	
POSITION OF CONNECTION FOR MAIN CURRENT CIRCUIT	Front side	
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	400 A	
RELEASE SYSTEM	Electronic release	
SHORT-CIRCUIT TOTAL BREAKTIME	< 10 ms	
RATED SHORT-TIME WITHSTAND CURRENT (T = 0.3 S)	3.3 kA	
RATED SHORT-TIME WITHSTAND CURRENT (T = 1 S)	3.3 kA	
SHORT-CIRCUIT RELEASE DELAYED SETTING - MAX	4000 A	
SHORT-CIRCUIT RELEASE DELAYED SETTING - MIN	320 A	
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MAX	4800 A	
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MIN	800 A	
TERMINAL CAPACITY (CONTROL CABLE)	0.75 mm <sup>2</sup> - 2.5 mm <sup>2</sup> (1x) 0.75 mm <sup>2</sup> - 1.5 mm <sup>2</sup> (2x)	
TERMINAL CAPACITY (COPPER BUSBAR)	Max. 10 mm x 50 mm (2x) at rear-side width extension Max. 30 mm x 10 mm + 30 mm x 5 mm direct at switch rear-side connection Min. 20 mm x 5 mm direct at switch rear-side connection M10 at rear-side screw connection	
TERMINAL CAPACITY (COPPER SOLID CONDUCTOR/CABLE)	16 mm² (2x) direct at switch rear-side connection 16 mm² (2x) at box terminal 300 mm² (2x) at rear-side	

	width extension 16 mm² (1x) at tunnel terminal 16 mm² (1x) direct at switch rear-side connection
TERMINAL CAPACITY (ALUMINUM SOLID CONDUCTOR/CABLE)	16 mm² (1x) at tunnel terminal
TERMINAL CAPACITY (COPPER STRANDED CONDUCTOR/CABLE)	25 mm² - 240 mm² (1x) direct at switch rear-side connection 25 mm² - 240 mm² (2x) direct at switch rear-side connection 25 mm² - 120 mm² (2x) at box terminal 16 mm² - 185 mm² (1x) at 1-hole tunnel terminal 35 mm² - 240 mm² (1x) at box terminal
TERMINAL CAPACITY (ALUMINUM STRANDED CONDUCTOR/CABLE)	50 mm <sup>2</sup> - 240 mm <sup>2</sup> (1x) at 2-hole tunnel terminal 25 mm <sup>2</sup> - 185 mm <sup>2</sup> (1x) at tunnel terminal 50 mm <sup>2</sup> - 240 mm <sup>2</sup> (2x) at 2-hole tunnel terminal
HANDLE TYPE	Rocker lever
SHORT DELAY CURRENT SETTING (ISD) - MAX	10 A
SHORT DELAY CURRENT SETTING (ISD) - MIN	2 A
INSTANTANEOUS CURRENT SETTING (II) - MAX	12 A
INSTANTANEOUS CURRENT SETTING (II) - MIN	2 A
NUMBER OF OPERATIONS PER HOUR - MAX	60
OVERLOAD CURRENT SETTING (IR) - MAX	400 A
OVERLOAD CURRENT SETTING (IR) - MIN	160 A
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 230 V, 50/60 HZ	85 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 400/415 V, 50/60 HZ	50 kA
RATED SHORT-CIRCUIT	35 kA

BREAKING CAPACITY ICS (IEC/EN 60947) AT 440 V, 50/60 HZ	
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 525 V, 50/60 HZ	13 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 690 V, 50/60 HZ	5 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 400/415 V, 50/60 HZ	110 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 440 V, 50/60 HZ	77 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 525 V, 50/60 HZ	55 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 690 V, 50/60 HZ	40 kA
STANDARD TERMINALS	Screw terminal
OPTIONAL TERMINALS	Box terminal. Connection on rear. Tunnel terminal
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 240 V, 50/60 HZ	187 kA
RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT AUXILIARY CONTACTS	6000 V
RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT MAIN CONTACTS	8000 V
RATED INSULATION VOLTAGE (UI)	690 V AC
PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	



DATE:

**Eaton Corporation plc** Eaton House

30 Pembroke Road Dublin 4, Ireland Eaton.com

 $\hbox{@ 2025 Eaton.}$  All Rights Reserved.

Follow us on social media to get the latest product and support information.









