

# Specifications



## Eaton 132608

Eaton Moeller® series M22 Illuminated selector switch actuator, RMQ-Titan, maintained, 3 positions, 1 NC, red, Blister pack for hanging

### General specifications

<b>PRODUCT NAME</b>	Eaton Moeller® series M22 Illuminated selector switch actuator
<b>CATALOG NUMBER</b>	132608
<b>MODEL CODE</b>	M22-WRLK3-R-2K01LED-BVP
<b>EAN</b>	4015081295531
<b>PRODUCT LENGTH/DEPTH</b>	30 mm
<b>PRODUCT HEIGHT</b>	210 mm
<b>PRODUCT WIDTH</b>	130 mm
<b>PRODUCT WEIGHT</b>	0.05 kg
<b>COMPLIANCES</b>	CE



Powering Business Worldwide

## Features & Functions

<b>BEZEL COLOR</b>	Titanium
<b>BEZEL MATERIAL</b>	Plastic
<b>FITTED WITH:</b>	Front ring

## Climatic environmental conditions

<b>AMBIENT OPERATING TEMPERATURE - MIN</b>	-25 °C
<b>AMBIENT OPERATING TEMPERATURE - MAX</b>	70 °C

## Contacts

<b>FORCE FOR POSITIVE OPENING - MIN</b>	0 N
---	-----

## General

<b>DEGREE OF PROTECTION</b>	NEMA 4X
<b>DEGREE OF PROTECTION (FRONT SIDE)</b>	IP66
<b>LIFESPAN, MECHANICAL</b>	100,000 Operations
<b>OPENING DIAMETER</b>	22.5 mm
<b>OVERVOLTAGE CATEGORY</b>	III
<b>POLLUTION DEGREE</b>	3
<b>SIZE</b>	Front diameter: 29.7 mm
<b>SUITABLE FOR</b>	Illumination

## Actuator

<b>ACTUATOR COLOR</b>	Black
<b>ACTUATOR FUNCTION</b>	Switching function latching
<b>ACTUATOR TYPE</b>	Toggle
<b>NUMBER OF SWITCH POSITIONS</b>	3

## Design verification

<b>EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID</b>	0 W
<b>HEAT DISSIPATION CAPACITY PDISS</b>	0 W
<b>HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT PVID</b>	0 W
<b>RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)</b>	0 A
<b>STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT PVS</b>	0 W
<b>10.2.2 CORROSION RESISTANCE</b>	Meets the product standard's requirements.
<b>10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES</b>	Meets the product standard's requirements.
<b>10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT</b>	Meets the product standard's requirements.
<b>10.2.3.3 RESIST. OF INSUL. MAT. TO</b>	Meets the product standard's requirements.

<b>ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS</b>	
<b>10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION</b>	Please enquire
<b>10.2.5 LIFTING</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.2.6 MECHANICAL IMPACT</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.2.7 INSCRIPTIONS</b>	Meets the product standard's requirements.
<b>10.3 DEGREE OF PROTECTION OF ASSEMBLIES</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.4 CLEARANCES AND CREEPAGE DISTANCES</b>	Meets the product standard's requirements.
<b>10.5 PROTECTION AGAINST ELECTRIC SHOCK</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS</b>	Does not apply, since the entire switchgear needs to be evaluated.
<b>10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS</b>	Is the panel builder's responsibility.
<b>10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS</b>	Is the panel builder's responsibility.
<b>10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH</b>	Is the panel builder's responsibility.
<b>10.9.3 IMPULSE WITHSTAND VOLTAGE</b>	Is the panel builder's responsibility.
<b>10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL</b>	Is the panel builder's responsibility.
<b>10.10 TEMPERATURE RISE</b>	Not applicable.
<b>10.11 SHORT-CIRCUIT RATING</b>	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
<b>10.12 ELECTROMAGNETIC COMPATIBILITY</b>	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
<b>10.13 MECHANICAL FUNCTION</b>	The device meets the requirements, provided the information in the instruction leaflet (IL) is

---

observed.

---

## Resources

	<a href="#">Flip catalog - Product Range Catalog - Command and indication</a>
CATALOGUES	<a href="#">eaton-rmq-titan-brochure-br047004en-en-us.pdf</a> <a href="#">eaton-pushbuttons-signal-towers-sensors-assortment-overview-catalog-ca047003en-en-us.pdf</a>
DECLARATIONS OF CONFORMITY	<a href="#">eaton-key-operated-actuator-declaration-of-conformity-eu250865en.pdf</a> <a href="#">eaton-key-operated-actuator-declaration-of-conformity-uk251348en.pdf</a> <a href="#">eaton-pushbutton-declaration-of-conformity-uk251341en.pdf</a> <a href="#">eaton-pushbutton-declaration-of-conformity-eu250858en.pdf</a>
DRAWINGS	<a href="#">eaton-general-m22-symbol.eps</a> <a href="#">eaton-general-m22-standards.eps</a> <a href="#">eaton-general-approval-m22-symbol.eps</a>
FLYERS	<a href="#">eaton-rmq-titan-selection-aid-brochure-fl047002-en-us.pdf</a>
INSTALLATION INSTRUCTIONS	<a href="#">IL04716002Z</a>
INSTALLATION VIDEOS	<a href="#">RMQ Flat Design</a>
MCAD MODEL	<a href="#">DA-CD-bg_wk_1led0</a> <a href="#">DA-CS-bg_wk_1led0</a>
MULTIMEDIA	<a href="#">easyE4 SmartWire-DT module with Remote Touch Display and RMQ multi color indicator</a> <a href="#">RMQ small E-Stop emergency-stop button</a> <a href="#">MCI MultiColor Light Indicator RMQ compact solution</a>

---

[MCI Multicolor Light Indicator M22 with SmartWire-DT](#)

[eaton-rmq-small-e-stop-flyer-fl047006en-en-us.pdf](#)

[eaton-rmq-flat-enclosure-flyer-fl047003en-en-us.pdf](#)

SALES NOTES

[eaton-control circuit-devices rmq-titan-fl144090en-en-us.pdf](#)

[eaton-rmq-mci-multi-color-light-indicator-flyer-fl047005en-en-us.pdf](#)

---

---

**PROJECT NAME:**

**PROJECT NUMBER:**

**PREPARED BY:**

**DATE:**

---



**Eaton Corporation plc**  
Eaton House  
30 Pembroke Road  
Dublin 4, Ireland  
Eaton.com

Follow us on social media to get the latest product and support information.

