Specifications



Photo is representative





Eaton 189638

NZMH4-PX1000-TAZ-AVE. NZM4 PXR25 circuit breaker - integrated energy measurement class 1, 1000A, 3p, Screw terminal, earth-fault protection, ARMS and zone selectivity

General specifications	
PRODUCT NAME	Eaton Moeller series NZM molded case circuit breaker electronic
CATALOG NUMBER	189638
MODEL CODE	NZMH4-PX1000-TAZ-AVE
EAN	4015081875856
PRODUCT LENGTH/DEPTH	501 mm
PRODUCT HEIGHT	280 mm
PRODUCT WIDTH	260 mm
PRODUCT WEIGHT	29 kg
COMPLIANCES	RoHS conform
CERTIFICATIONS	IEC/EN 60947 IEC
GLOBAL CATALOG	189638



Product specification	S
AMPERAGE RATING	1000 A
VOLTAGE RATING	690 V - 690 V
CIRCUIT BREAKER FRAME TYPE	NZM4
FEATURES	Protection unit Motor drive optional
ACCESSORIES REQUIRED	NZM4-XAVS
10.10 TEMPERATURE RISE	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Meets the product standard's requirements.
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.

	Resources	
	BROCHURES	eaton-digital-nzm- brochure-br013003en-en- us.pdf
	BROCHORES	eaton-feerum-the-whole- grain-solution-success- story-en-us.pdf
	CATALOGS	eaton-digital-nzm-catalog- ca013003en-en-us.pdf
II :ion	DECLARATIONS OF CONFORMITY	eaton-molded-case-circuit- breaker-declaration-of- conformity- eu250294en.pdf
		eaton-circuit-breaker-nzm- mccb-dimensions-022.eps
DRAWINGS	DRAWINGS	eaton-circuit-breaker- withdrawable-unit-nzm- mccb-dimensions.eps
	INSTALLATION INSTRUCTIONS	eaton-circuit-breaker- basic-unit-bg4- il012101zu.pdf
	INSTALLATION VIDEOS	Introduction of the new digital circuit breaker NZM
e led	INSTALLATION VIDEOS	The new digital NZM Range
e) is	MCAD MODEL	DA-CS-nzm4_3p DA-CD-nzm4_3p
ents.	PEP ECO-PASSPORT	eaton-molded-case- switches-pep-eato-00243- v0101-en.pdf
ents.	TECHNICAL DATA SHEETS	eaton-nzm-technical- information-sheet

10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	ls the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	ls the panel builder's responsibility.
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	Is the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	ls the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF	ls the panel builder's
INSULATING MATERIAL	responsibility.
	responsibility.
INSULATING MATERIAL	
POLLUTION DEGREE	3 Built-in device slide-in technique (withdrawable)
INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD	Built-in device slide-in technique (withdrawable) Withdrawable Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to
INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT-	Built-in device slide-in technique (withdrawable) Withdrawable Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78
INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT	Built-in device slide-in technique (withdrawable) Withdrawable Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78
INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY	Built-in device slide-in technique (withdrawable) Withdrawable Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 123 W B (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the
INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY ISOLATION AMBIENT OPERATING	Built-in device slide-in technique (withdrawable) Withdrawable Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 123 W B (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts)
INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY ISOLATION AMBIENT OPERATING TEMPERATURE - MAX AMBIENT OPERATING	Built-in device slide-in technique (withdrawable) Withdrawable Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 123 W B (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) 70 °C
INSULATING MATERIAL POLLUTION DEGREE MOUNTING METHOD CLIMATIC PROOFING EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT UTILIZATION CATEGORY ISOLATION AMBIENT OPERATING TEMPERATURE - MAX AMBIENT OPERATING TEMPERATURE - MIN AMBIENT STORAGE	Built-in device slide-in technique (withdrawable) Withdrawable Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 123 W B (IEC/EN 60947-2) 500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) 70 °C -25 °C

0
0
0
Finger and back-of-hand proof to VDE 0106 part 100
IP20 (basic degree of protection, in the operating controls area) IP20
As required
Other
10000 operations
III
IP66 (with door coupling rotary handle) IP40 (with insulating surround)
IP00 (terminations, phase isolator and strip terminal)
IP10 (tunnel terminal)
IP10 (tunnel terminal) Three-pole

	3000 operations at 400 V AC-1 3000 operations at 415 V AC-1
FUNCTIONS	Systems, cable, selectivity and generator protection ARMS maintenance mode Earth-fault protection Integrated earth fault protection Zone selectivity
EARTH-FAULT CURRENT SETTING (IG) - MAX	1000 x In
ТҮРЕ	Circuit breaker
SPECIAL FEATURES	 LSIG overload protection and delayed and non-delayed short-circuit protective device, earth-fault protection Class 1 energy measurement, r.m.s. value measurement, and "thermal memory" USB interface for configuration and test function with Power Xpert Protection Manager software Zone selectivity ZSI Maintenance Mode ARMS Interface module in equipment supplied. Optionally communication-capable with internal Modbus RTU module or CAM Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit breaking capacity lcn) Rated current =

	rated uninterrupted current: 1000 A
APPLICATION	525 V
SHOCK RESISTANCE	15 g (half-sinusoidal shock 11 ms)
EARTH-FAULT CURRENT SETTING (IG) - MIN	200 x In
POSITION OF CONNECTION FOR MAIN CURRENT CIRCUIT	Connection at separate chassis part
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	1000 A
RELEASE SYSTEM	Electronic release
SHORT-CIRCUIT TOTAL BREAKTIME	< 25 ms (415 V); < 35 ms (> 415 V)
RATED SHORT-TIME WITHSTAND CURRENT (T = 0.3 S)	19.2 kA
RATED SHORT-TIME WITHSTAND CURRENT (T = 1 S)	19.2 kA
SHORT-CIRCUIT RELEASE DELAYED SETTING - MAX	10 A
SHORT-CIRCUIT RELEASE DELAYED SETTING - MIN	2 A
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MAX	18 A
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MIN	2 A
TERMINAL CAPACITY (CONTROL CABLE)	0.75 mm ² - 2.5 mm ² (1x) 0.75 mm ² - 1.5 mm ² (2x)
TERMINAL CAPACITY (COPPER BUSBAR)	50 mm x 10 mm (2x) at rear-side 2-hole module plate Max. 80 mm x 10 mm (2x) at rear-side width extension Min. 25 mm x 5 mm direct at switch rear-side connection Min. 60 mm x 10 mm at rear-side width extension Min. 25 mm x 5 mm at rear-side 1-hole module plate Max. 50 mm x 10 mm (2x) at rear-side 1-hole module plate

	Max. 50 mm x 10 mm (2x) direct at switch rear-side connection M10 at rear-side screw connection
TERMINAL CAPACITY (COPPER SOLID CONDUCTOR/CABLE)	95 mm² - 240 mm² (6x) at rear-side width extension 35 mm² - 185 mm² (4x) at rear-side 2-hole module plate 50 mm² - 240 mm² (4x) at 4-hole tunnel terminal 95 mm² - 185 mm² (2x) at rear-side 2-hole module plate 95 mm² - 300 mm² (2x) at rear-side 1-hole module plate 120 mm² - 300 mm² (1x) at rear-side 1-hole module plate 300 mm² (4x) at rear-side width extension
TERMINAL CAPACITY (COPPER STRANDED CONDUCTOR/CABLE)	120 mm ² - 185 mm ² (1x) direct at switch rear-side connection 50 mm ² - 185 mm ² (4x) direct at switch rear-side connection
TERMINAL CAPACITY (ALUMINUM STRANDED CONDUCTOR/CABLE)	50 mm² - 240 mm² (4x) at 4-hole tunnel terminal
HANDLE TYPE	Rocker lever
SHORT DELAY CURRENT SETTING (ISD) - MAX	10 A
SHORT DELAY CURRENT SETTING (ISD) - MIN	2 A
INSTANTANEOUS CURRENT SETTING (II) - MAX	18 A
INSTANTANEOUS CURRENT SETTING (II) - MIN	2 A
NUMBER OF OPERATIONS PER HOUR - MAX	60
OVERLOAD CURRENT SETTING (IR) - MAX	1000 A
OVERLOAD CURRENT SETTING (IR) - MIN	400 A
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 230 V, 50/60 HZ	63 kA

RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 400/415 V, 50/60 HZ	50 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 440 V, 50/60 HZ	50 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 525 V, 50/60 HZ	37 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 690 V, 50/60 HZ	37 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 400/415 V, 50/60 HZ	187 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 440 V, 50/60 HZ	187 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 525 V, 50/60 HZ	143 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 690 V, 50/60 HZ	100 kA
STANDARD TERMINALS	Screw connection
OPTIONAL TERMINALS	Connection on rear. Strip terminal. Tunnel terminal
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 240 V, 50/60 HZ	275 kA
RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT AUXILIARY CONTACTS	6000 V
RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT MAIN CONTACTS	8000 V
RATED INSULATION VOLTAGE (UI)	1000 V AC

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
DATE:	



Eaton Corporation plc Eaton House 30 Pembroke Road Dublin 4, Ireland Eaton.com

© 2025 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.









