



Ref. Certif. No.

CN46224

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Name and address of the manufacturer

Name and address of the factory

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

Auxiliary Contacts

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

ABB Stotz-Kontakt GmbH
Eppelheimer Strasse 82 69123 Heidelberg Germany

ABB Bulgaria EOOD
1, Varna Str., 2850 Petrich, Bulgaria

Uimp:6kV; Ui:250V; Ith:5A; Ue/Ie:AC-15:AC24V/3A,
120V/3A, 240V/1.5A; DC-13:DC24V/1A, 125V/0.27A,
250V/0.11A; IP20

ABB

HKF1-xx, HKF1-xxK

IEC 60947-5-1:2016(4th Edition)

00901-CB2018CQC-084736

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Mar.25,2019

Signature:

Lu Mei



CB 0050529

Description of Sample Type:

HKF1	-	20	K
1		2	3

1	HKF1-.. Auxiliary contacts for front mounting
2	Contact Configuration: 11: 1 N.O. and 1 N.C. contact 20: 2 N.O. contact 10: 1 N.O. contact 01: 1 N.C. contact
3	Blank: : Standard version (screw terminal) K: Push In terminal

Page 1 of 1

Additional information (if necessary)

Date: Mar.25,2019

Signature:



Lu Mei