



Overview

Specifications

Resources







## Delivery program

## **DELIVERY PROGRAM**

Technical data

Product range Main switch maintenance switch Repair switch

Design verification as per IEC/EN 61439

Part group reference

T5

Technical data ETIM 7.0

Stop Function

Emergency switching off function

Dimensions

With red rotary handle and yellow locking ring

Number of poles 1 pole

Degree of Protection Front IP65

Design flush mounting



Con	tact sec	quence
-	Χ	
0		
	10	

Switching angle 90  $^{\circ}$ 

Design number 8200

#### **Function**



# Motor rating AC-23A, 50 - 60 Hz [P]

400 V [P] 55 kW

Rated uninterrupted current  $[I_u]$  100 A

Note on rated uninterrupted current  $I_u$  Rated uninterrupted current  $I_u$  is specified for max. cross-section.

Number of contact units 1 contact unit(s)

## **TECHNICAL DATA**

## **General**

Standards
IEC/EN 60947, VDE 0660, IEC/EN 60204
Switch-disconnector according to IEC/EN 60947-3

Olimatic proofing Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30

Ambient temperature Open -25 - +50 °C

Ambient temperature Enclosed -25 - +40 °C

Overvoltage category/pollution degree III/3

Rated impulse withstand voltage [ $U_{mp}$ ] 6000 V AC

Mechanical shock resistance 15 g

Mounting position As required

#### **Contacts**

Mechanical variables Number of poles 1 pole

Bectrical characteristics Rated operational voltage [U<sub>e</sub>] 690 V AC

Bectrical characteristics
Rated uninterrupted current [I<sub>u</sub>]
100 A

 $\label{eq:local_local} \mbox{ Bectrical characteristics } \mbox{ Note on rated uninterrupted current $l_u$ } \mbox{ Rated uninterrupted current $l_u$ is specified for max. cross-section.}$ 

Load rating with intermittent operation, class 12 AB 25 % DF  $_2\,x$   $I_{\!_{\rm B}}$ 

Load rating with intermittent operation, class 12 AB 40 % DF 1.6 x  $I_{\rm e}$ 

Load rating with intermittent operation, class 12 AB 60 % DF 1.3 x  $I_{\rm e}$ 

Short-circuit rating Fuse 100 A gG/gL

Rated short-time withstand current (1 s current)  $[I_{\text{cw}}]$  1700  $A_{\text{rms}}$ 

Note on rated short-time withstand current lcw Current for a time of 1 second

Rated conditional short-circuit current  $[I_q]$  2 kA

## **Switching capacity**

cos φ rated making capacity as per IEC 60947-3 950 A

Rated breaking capacity cos  $\varphi$  to IEC 60947-3 230 V 760 A

Rated breaking capacity cos  $\varphi$  to IEC 60947-3 400/415 V 740 A

Rated breaking capacity cos  $\phi$  to IEC 60947-3 500 V 590 A

Rated breaking capacity cos  $\varphi$  to IEC 60947-3 690 V 420 A

Safe isolation to EN 61140 between the contacts 440 V AC

Safe isolation to BN 61140 Current heat loss per contact at  $\rm l_e$   $7.5~\rm W$ 

Safe isolation to EN 61140 Ourrent heat loss per auxiliary circuit at  $\rm I_{\rm e}$  (AC-15/230 V) 7.5 CO

Lifespan, mechanical [Operations] > 0.5 x 10<sup>6</sup>

Maximum operating frequency [Operations/h] 1200

AC AC-3 Rating, motor load switch [P] 220 V 230 V [P] 22 kW

AC AC-3 Rating, motor load switch [P] 230 V Star-delta [P] 30 kW

AC AC-3 Rating, motor load switch [P] 400 V 415 V [P] 30 kW

AC AC-3 Rating, motor load switch [P] 400 V Star-delta [P] 45 kW

AC AC-3 Rating, motor load switch [P] 500 V [P] 30 kW AC AC-3 Rating, motor load switch [P] 500 V Star-delta [P] 45 kW

AC AC-3 Rating, motor load switch [P] 690 V [P] 15 kW

AC AC-3 Rating, motor load switch [P] 690 V Star-delta [P] 22 kW

AC AC-3 Rated operational current motor load switch 230 V [ $_{\rm b}$ ] 71 A

AC
AC-3
Rated operational current motor load switch
230 V star-delta [l<sub>e</sub>]
100 A

AC AC-3 Rated operational current motor load switch 400V 415 V [le]  $55\,\mathrm{A}$ 

AC
AC-3
Rated operational current motor load switch
400 V star-delta [l<sub>e</sub>]
95.3 A

AC AC-3 Rated operational current motor load switch 500 V [l\_e]  $\,$  44 A

AC AC-3 Rated operational current motor load switch 500 V star-delta [I $_{\rm e}$ ]

AC
AC-3
Rated operational current motor load switch
690 V [I<sub>e</sub>]
17 A

AC
AC-3
Rated operational current motor load switch
690 V star-delta [I<sub>e</sub>]
29.4 A

AC AC-23A Motor rating AC-23A, 50 - 60 Hz [P] 230 V [P] 30 kW

AC AC-23A Motor rating AC-23A, 50 - 60 Hz [P] 400 V 415 V [P] 55 kW

AC AC-23A Motor rating AC-23A, 50 - 60 Hz [P] 500 V [P] 37 kW

AC AC-23A Motor rating AC-23A, 50 - 60 Hz [P] 690 V [P] 30 kW

AC AC-23A Rated operational current motor load switch 230 V [ $l_{e}$ ] 100 A

AC
AC-23A
Rated operational current motor load switch
400 V 415 V [la]
100 A

AC AC-23A Rated operational current motor load switch 500 V [ $_{\rm e}$ ] 55 A

AC
AC-23A
Rated operational current motor load switch
690 V [I<sub>e</sub>]
32 A

DC DC-1, Load-break switches L/R=1 ms Rated operational current [l<sub>e</sub>] 80 A

DC
DC-1, Load-break switches L/R=1 ms
Voltage per contact pair in series
60 V

Control circuit reliability at 24 V DC, 10 mA [Fault probability]  $< 10^{-5}, < 1$  failure in 100,000 switching operations H<sub>=</sub>

#### **Terminal capacities**

Solid or stranded 1 x (2,5 - 35) 2 x (2,5 - 16) mm<sup>2</sup>

Flexible with ferrules to DIN 46228 1 x (1 - 25) 2 x (1.5 - 10) mm<sup>2</sup>

Terminal screw M6

Tightening torque for terminal screw 4 Nm

## **Technical safety parameters:**

#### Notes

B10<sub>d</sub> values as per EN ISO 13849-1, table C1

## Rating data for approved types

Contacts
Rated operational voltage [U<sub>e</sub>]
600 V AC

Contacts
Rated uninterrupted current max.
Main conducting paths
General use
65 A

Terminal capacity
Terminal screw
M6

## **DESIGN VERIFICATION AS PER IEC/EN 61439**

## Technical data for design verification

Rated operational current for specified heat dissipation [ $I_n$ ] 100 A

Heat dissipation per pole, current-dependent  $[P_{\text{id}}]$  7.5 W

Equipment heat dissipation, current-dependent  $[P_{vid}]$ 

Static heat dissipation, non-current-dependent  $[P_{\!\scriptscriptstyle NS}]$  0 W

Heat dissipation capacity  $[P_{diss}]$  0 W

0 W

Operating ambient temperature min.  $-25 \, ^{\circ}\mathrm{C}$ 

Operating ambient temperature max. +50  $^{\circ}$ C

IEC/EN 61439 design verification

10.2 Strength of materials and parts10.2.2 Corrosion resistanceWeets the product standard's requirements.

10.2 Strength of materials and parts 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements.

10.2 Strength of materials and parts10.2.3.2 Verification of resistance of insulating materials to normal heatWeets the product standard's requirements.

10.2 Strength of materials and parts 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects Weets the product standard's requirements.

10.2 Strength of materials and parts10.2.4 Resistance to ultra-violet (UV) radiationUV resistance only in connection with protective shield.

10.2 Strength of materials and parts10.2.5 LiftingDoes not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts10.2.6 Mechanical impactDoes not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts10.2.7 InscriptionsMeets the product standard's requirements.

10.3 Degree of protection of ASSEVBLIES Does not apply, since the entire switchgear needs to be evaluated.

10.4 Clearances and creepage distances Meets the product standard's requirements.

10.5 Protection against electric shock
Does not apply, since the entire switchgear needs

to be evaluated.

10.6 Incorporation of switching devices and components

Does not apply, since the entire switchgear needs to be evaluated.

10.7 Internal electrical circuits and connections Is the panel builder's responsibility.

10.8 Connections for external conductors Is the panel builder's responsibility.

10.9 Insulation properties 10.9.2 Power-frequency electric strength Is the panel builder's responsibility.

10.9 Insulation properties 10.9.3 Impulse withstand voltage Is the panel builder's responsibility.

10.9 Insulation properties10.9.4 Testing of enclosures made of insulating materialIs the panel builder's responsibility.

10.10 Temperature rise
The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.

10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed.


10.13 Mechanical function
The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

## **TECHNICAL DATA ETIM 7.0**

Low-voltage industrial components (EG000017) / Switch disconnector (EC000216)

Bectric engineering, automation, process control engineering / Low-voltage switch technology / Off-load switch, circuit breaker, control switch / Switch disconnector (ecl@ss10.0.1-27-37-14-03 [AKF060013]) Version as main switch Yes Version as maintenance-/service switch Yes Version as safety switch Version as emergency stop installation Yes Version as reversing switch Number of switches Max. rated operation voltage Ue AC 690 V Rated operating voltage 690 - 690 V Rated permanent current lu 100 A Rated permanent current at AC-23, 400 V 100 A Rated permanent current at AC-21, 400 V 100 A Rated operation power at AC-3, 400 V

30 kW



Suitable for front mounting centre Yes	
Suitable for distribution board installation No	
Suitable for intermediate mounting No	
Colour control element Red	
Type of control element Door coupling rotary drive	
Interlockable Yes	
Type of electrical connection of main circuit Screw connection	
Degree of protection (IP), front side IP65	
Degree of protection (NEVA) Other	

## **DIMENSIONS**



□ ZFS-... Label mount not included as standard □ Drilling dimensions door Camswitches T5B and T5 are of identical design, only their contacts are different



☐ 3 padlocks







Imprint | Privacy Policy | Legal Disclaimer | Terms and Conditions © 2021 by Eaton Industries GmbH