#### **DATASHEET - PKZM0-XDM32ME**



#### Wiring module, for DILM17-M38, for screw terminals

Powering Business Worldwide\*

Part no. PKZM0-XDM32ME
Catalog No. 190312
Alternate Catalog XTPAXEMCC

### **Delivery program**

| Product range | Accessories   |
|---------------|---|
| Accessories   | Wiring set  |
|               | DOL starter Electrical/mechanical connector for screw terminals                 |
| For use with  | PKZM0, PKE + DILM17 PKZM0, PKE + DILM25 PKZM0, PKE + DILM32 PKZM0, PKE + DILM38 |

# Design verification as per IEC/EN 61439

| Design Verification as per IEC/EN 61439   |                   |    |  |
|---|-------------------|----|--|
| Technical data for design verification  |                   |    |  |
| Rated operational current for specified heat dissipation  | In                | Α  | 32   |
| Static heat dissipation, non-current-dependent  | P <sub>vs</sub>   | W  | 0  |
| Heat dissipation capacity   | P <sub>diss</sub> | W  | 0  |
| Operating ambient temperature min.  |                   | °C | -25  |
| Operating ambient temperature max.  |                   | °C | 55   |
| IEC/EN 61439 design verification  |                   |    |  |
| 10.2 Strength of materials and parts  |                   |    |  |
| 10.2.2 Corrosion resistance   |                   |    | Meets the product standard's requirements.   |
| 10.2.3.1 Verification of thermal stability of enclosures  |                   |    | Meets the product standard's requirements.   |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat  |                   |    | Meets the product standard's requirements.   |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $$ |                   |    | Meets the product standard's requirements.   |
| 10.2.4 Resistance to ultra-violet (UV) radiation  |                   |    | Meets the product standard's requirements.   |
| 10.2.5 Lifting  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 Mechanical impact  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.7 Inscriptions   |                   |    | Meets the product standard's requirements.   |
| 10.3 Degree of protection of ASSEMBLIES   |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.4 Clearances and creepage distances  |                   |    | Meets the product standard's requirements.   |
| 10.5 Protection against electric shock  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.6 Incorporation of switching devices and components  |                   |    | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.7 Internal electrical circuits and connections   |                   |    | Is the panel builder's responsibility.   |
| 10.8 Connections for external conductors  |                   |    | Is the panel builder's responsibility.   |
| 10.9 Insulation properties  |                   |    |  |
| 10.9.2 Power-frequency electric strength  |                   |    | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage  |                   |    | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material  |                   |    | Is the panel builder's responsibility.   |
| 10.10 Temperature rise  |                   |    | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating  |                   |    | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.12 Electromagnetic compatibility   |                   |    | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 Mechanical function   |                   |    | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |


#### **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Wiring set for power circuit breaker (EC002050)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Circuit breaker (LV < 1 kV) / Wiring set for circuit breaker (ecl@ss10.0.1-27-37-04-24 [ACN957011])

| Suitable for number of poles | 3              |
|------------------------------|----------------|
| Model                        | Direct circuit |

## **Dimensions**



# **Assets (links)**

**Declaration of CE Conformity** 

00002851

**Instruction Leaflets** 

IL034054ZU2018\_06