

# **CERTIFICATE**

#### No. P09211632





Order No. 131751 Page 1/3 **Product** Socket-outlet **Applicant** Paul Hochkopper GmbH & Co. KG Gartenstrasse 49 58511 Ludenscheid Germany Manufacturer Paul Hochkopper GmbH & Co. KG Gartenstrasse 49 58511 Ludenscheid Germany **Factory PEHA** Paul Hochköpper GmbH & Co. KG, Daimlerstr. 4 Halver 58553 Germany ☐ See next page(s) Ratings 16A 250V AC Trade mark **PEHA** 6211... EMS SI Model / Type Ref. Principal characteristics Socket-outlet for fixed installation. Standard Sheet III. Thermoplastic, for flush mounting into ducting systems, one gang with horisontal socket inlet, with shutters and screwless terminals, all colours. IP20 See next page(s) A sample of the product was tested INST NEK-IEC 60884-1:2002;am1 and NEK 502:2006 and found to be in conformity with Validity This certificate documents conformity with the standards shown, and also applies as license for use

This certificate documents conformity with the standards shown, and also applies as license for use of Nemkos name and certification mark. The certificate and license is valid as long as the applicable conditions are complied with, and provided that any changes to the product are notified

to Nemko for acceptance prior to implementation.

New standards or amendments to the standards may imply that the product design must be

updated and/or that re-testing and re-certification is necessary.

Additional information

See next page(s)

Additional model(s)

See next page(s)

Date of issue 18-12-2009

True . 3. Lleppenes

Signature

Juan Z. Kleppenes
Certification Department

Nemko ASOffice addressInternetTelephoneFaxP.O. Box 73, BlindernGaustadalléen 30www.nemko.com+47 22 96 03 30+ 47 22 96 05 50N-0314 Oslo, NorwayOsloEnterprise number:NO 974404532



### **CERTIFICATE**

#### No. P09211632





Order No. 131751 Page 2/3

Product Socket-outlet

Pos. No

Model / Type Ref. 6211... EMS SI WI

Trade mark (if different from page 1)

Rating 16A 250V AC

Principal characteristics Socket-outlet for fixed installation. Standard Sheet III. Thermoplastic, for

flush mounting into ducting systems, one gang with 45 degree angel socket

inlet, with shutters and screwless terminals, all colours. IP20

Product Socket-outlet

Pos. No 2

Model / Type Ref. 6212... EMS SI

Trade mark (if different from page 1)

Rating 16A 250V AC

Principal characteristics Socket-outlet for fixed installation. Standard Sheet III. Thermoplastic, for

flush mounting into ducting systems, two gang with horisontal socket inlet,

with shutters and screwless terminals, all colours. IP20

Product Socket-outlet

Pos. No 3

Model / Type Ref. 6212... EMS SI WI

Trade mark (if different from page 1)

Rating 16A 250V AC

Principal characteristics Socket-outlet for fixed installation. Standard Sheet III. Thermoplastic, for

flush mounting into ducting systems, two gang with 45 degree angel socket

inlet, with shutters and screwless terminals, all colours. IP20

Product Socket-outlet

Pos. No 4

Model / Type Ref. 6213... EMS SI

Trade mark (if different from page 1)

Rating 16A 250V AC

Principal characteristics Socket-outlet for fixed installation. Standard Sheet III. Thermoplastic, for

flush mounting into ducting systems, three gang with horisontal socket inlet,

with shutters and screwless terminals, all colours. IP20

Date of issue 18-12-2009

June . 3. Kleppenes

Signature

Juan Z. Kleppenes
Certification Department

Nemko AS Office address Internet Telephone Fax

P.O. Box 73, Blindern Gaustadalléen 30 www.nemko.com +47 22 96 03 30 + 47 22 96 05 50

N-0314 Oslo, Norway Oslo Enterprise number: NO 974404532



## **CERTIFICATE**

#### No. P09211632





Order No. 131751 Page 3/3

Product Socket-outlet

Pos. No 5

Model / Type Ref. 6213... EMS SI WI

Trade mark (if different from page 1)

Rating 16A 250V AC

Principal characteristics Socket-outlet for fixed installation. Standard Sheet III. Thermoplastic, for

flush mounting into ducting systems, three gang with 45 degree angel socket

inlet, with shutters and screwless terminals, all colours. IP20

Date of issue 18-12-2009

Signature

Juan Z. Kleppenes
Certification Department

P.O. Box 73, Blindern

Nemko AS Office address

Gaustadalléen 30

Internet

www.nemko.com

Telephone

Fax

+47 22 96 03 30

+ 47 22 96 05 50

N-0314 Oslo, Norway Oslo

Enterprise number:

NO 974404532