



256790

FAK-R/V/KC02/IY

[Overview](#)[Specifications](#)[Resources](#)

## DELIVERY PROGRAM

[Delivery program](#)

Product range  
Foot and palm switches

[Technical data](#)

Basic function  
Complete devices

[Design verification as per IEC/EN 61439](#)

Single unit/Complete unit  
Complete unit

[Technical data ETIM 7.0](#)

Function  
maintained

[Approvals](#)

Description  
Pull to release  
Emergency stop pushbutton tamper-proof to ISO 13850/EN 418

[Dimensions](#)

## Contacts

N/C = Normally closed  
2 NC

Notes

= safety function, by positive opening to IEC/EN  
60947-5-1

**Colour**

Button  
Red



enclosure top  
Yellow



Enclosure base  
Black



Approval



Connection to SmartWire-DT  
no

## TECHNICAL DATA

## General

Standards  
IEC/EN 60947-5-5, VDE 0660

Lifespan, mechanical [Operations]  
 $> 0.1 \times 10^6$

Operating frequency [Operations/h]  
 600

Actuating force  
40 - 60 N

Degree of protection, IEC/EN 60529  
IP66, IP67, IP69

Climatic proofing  
Damp heat, constant, to IEC 60068-2-78  
Damp heat, cyclic, to IEC 60068-2-30

Ambient temperature  
Open  
-25 - +55 °C

Mounting position  
As required

Mechanical shock resistance  
 $> 15$   
Shock duration 11 ms  
Sinusoidal  
according to IEC 60068-2-27 g

## DESIGN VERIFICATION AS PER IEC/EN 61439

### Technical data for design verification

Rated operational current for specified heat  
dissipation [ $I_h$ ]  
6 A

Heat dissipation per pole, current-dependent [ $P_{vid}$ ]  
0.11 W

Equipment heat dissipation, current-dependent  
[ $P_{vid}$ ]  
0 W

Static heat dissipation, non-current-dependent [ $P_{vs}$ ]  
0 W

Heat dissipation capacity [ $P_{diss}$ ]  
0 W

Operating ambient temperature min.  
-25 °C

Operating ambient temperature max.  
+55 °C

### IEC/EN 61439 design verification

10.2 Strength of materials and parts  
10.2.2 Corrosion resistance  
Meets the product standard's requirements.

10.2 Strength of materials and parts  
10.2.3.1 Verification of thermal stability of  
enclosures  
Meets the product standard's requirements.

10.2 Strength of materials and parts  
10.2.3.2 Verification of resistance of insulating  
materials to normal heat  
Meets the product standard's requirements.

10.2 Strength of materials and parts  
10.2.3.3 Verification of resistance of insulating  
materials to abnormal heat and fire due to internal  
electric effects  
Meets the product standard's requirements.

10.2 Strength of materials and parts  
10.2.4 Resistance to ultra-violet (UV) radiation  
Please enquire

10.2 Strength of materials and parts  
10.2.5 Lifting

Does not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts

10.2.6 Mechanical impact

Does not apply, since the entire switchgear needs to be evaluated.

10.2 Strength of materials and parts

10.2.7 Inscriptions

Meets the product standard's requirements.

10.3 Degree of protection of ASSEMBLIES

Does not apply, since the entire switchgear needs to be evaluated.

10.4 Clearances and creepage distances

Meets the product standard's requirements.

10.5 Protection against electric shock

Does not apply, since the entire switchgear needs to be evaluated.

10.6 Incorporation of switching devices and components

Does not apply, since the entire switchgear needs to be evaluated.

10.7 Internal electrical circuits and connections

Is the panel builder's responsibility.

10.8 Connections for external conductors

Is the panel builder's responsibility.

10.9 Insulation properties

10.9.2 Power-frequency electric strength

Is the panel builder's responsibility.

10.9 Insulation properties

10.9.3 Impulse withstand voltage

Is the panel builder's responsibility.

10.9 Insulation properties

10.9.4 Testing of enclosures made of insulating material

Is the panel builder's responsibility.

#### 10.10 Temperature rise

Is the panel builder's responsibility for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.

#### 10.11 Short-circuit rating

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

#### 10.12 Electromagnetic compatibility

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

#### 10.13 Mechanical function

The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

## TECHNICAL DATA ETIM 7.0

Low-voltage industrial components (EG000017) / Foot-/palm switch complete (EO000231)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Command and alarm device / Foot, palm switch (ecl@ss10.0.1-27-37-12-17 [AKF035014])

Unlocking method  
Pull-release

Colour cap  
Red

Number of contacts as normally open contact  
0

Number of contacts as normally closed contact  
2

Switching function latching  
Yes

Spring-return

Nb

Hole diameter  
0 mm

Degree of protection (IP)  
IP67/IP69K

Degree of protection (NEMA)  
4X

## APPROVALS

Product Standards  
IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05;  
CSA-C22.2 No. 94-91; CE marking

UL File No.  
E29184

UL Category Control No.  
NKCR

CSA File No.  
012528

CSA Class No.  
3211-03

North America Certification  
UL listed, CSA certified

Degree of Protection  
UL/CSA Type 3R, 4X, 12, 13

## DIMENSIONS



3 x M20 (PG 13.5) on the side  
1 x M16 in the base

