# **DATASHEET - M22-KC03SMC10**



# Contact element 3 N/C, base fixing, screw connection, self-monitoring



Part no. Catalog No.

Alternate Catalog

**EL-Nummer** 4315277

(Norway)

### M22-KC03SMC10 173028

M22-KC03SMC10

Powering Business Worldwide

| 110 | livery | nro | Trom    |
|-----|--------|-----|---------|
| UC  | IIVEIV | uiu | JI AIII |
|     |        |     |         |

| Delivery program   |    |   |
|--|----|---|
| Basic function accessories   |    | Self-monitoring contact elements  |
| Description  |    | The N/O in the self-monitoring contact element is actuated when mounted with $\mbox{M22-XSMC}.$ |
| Connection technique   |    | Screw terminals   |
| Fixing   |    | Base fixing   |
| Degree of Protection   |    | IP20  |
| Connection to SmartWire-DT   |    | no  |
| Approval   |    | ET 16107 Sicherheit geprüft tested safety   |
| Contacts   |    |   |
| N/O = Normally open  |    | 1 N/0   |
| N/C = Normally closed  |    | 3 NC →  |
| Notes  |    | = safety function, by positive opening to IEC/EN 60947-5-1                                      |
| Actuator travel and actuation force as per DIN EN 60947-5-1, K.5.4.1 |    |   |
|  | mm | 4.8   |
| Maximum travel   | mm | 5.7   |
| Minimum force for positive opening                                   | N  | 45  |
| Contact sequence   |    | $ \begin{array}{c ccccccccccccccccccccccccccccccccccc$  |
| Contact travel diagram, stroke in connection with front element      |    |   |
| Contact diagram  |    | 2.8<br>0 1.2 5.5  |
| Connection technique   |    | Screw terminals   |
|  |    |   |

# **Technical data**

| delleral                           |    |   |
|------------------------------------|----|---|
| Standards                          |    | IEC 60947-5-1   |
| Actuating force                    | n  | ≦ 15  |
| Operating torque (screw terminals) | Nm | ≦ 0.8   |
| Degree of Protection               |    | IP20  |
| Climatic proofing                  |    | Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30 |
| Ambient temperature                |    |   |

| Open                                    |                  | °C              | -25 - +70         |
|---|------------------|-----------------|-------------------|
| Terminal capacities                     |                  | $mm^2$          |                   |
| Solid                                   |                  | $\text{mm}^2$   | 0.75 - 2.5        |
| Stranded                                |                  | mm <sup>2</sup> | 0.5 - 2.5         |
| Flexible with ferrule                   |                  | $\text{mm}^2$   | 0.5 - 1.5         |
| Contacts                                |                  |                 |                   |
| Rated impulse withstand voltage         | U <sub>imp</sub> | V AC            | 6000              |
| Rated insulation voltage                | Ui               | V               | 500               |
| Overvoltage category/pollution degree   |                  |                 | III/3             |
| Max. short-circuit protective device    |                  |                 |                   |
| Fuseless                                |                  | Туре            | PKZM0-10/FAZ-B6/1 |
| Fuse                                    | gG/gL            | Α               | 10                |
| Switching capacity                      |                  |                 |                   |
| Rated operational current               | I <sub>e</sub>   | Α               |                   |
| AC-15                                   |                  |                 |                   |
| 115 V                                   | I <sub>e</sub>   | Α               | 6                 |
| 220 V 230 V 240 V                       | I <sub>e</sub>   | Α               | 6                 |
| 380 V 400 V 415 V                       | I <sub>e</sub>   | Α               | 4                 |
| 500 V                                   | I <sub>e</sub>   | Α               | 2                 |
| DC-13                                   |                  |                 |                   |
| 24 V                                    | I <sub>e</sub>   | Α               | 3                 |
| 42 V                                    | I <sub>e</sub>   | Α               | 1.7               |
| 60 V                                    | I <sub>e</sub>   | Α               | 1.2               |
| 110 V                                   | I <sub>e</sub>   | Α               | 0.6               |
| 220 V                                   | I <sub>e</sub>   | Α               | 0.3               |
| Auxiliary contacts                      |                  |                 |                   |
| Rated conditional short-circuit current | Iq               | kA              | 1                 |
|   |                  |                 |                   |

## **Design verification as per IEC/EN 61439**

| Design verification as per IEC/EN 61439  |                   |    |  |
|--|-------------------|----|--|
| Technical data for design verification   |                   |    |  |
| Rated operational current for specified heat dissipation   | In                | Α  | 6  |
| Heat dissipation per pole, current-dependent   | P <sub>vid</sub>  | W  | 0.11   |
| Equipment heat dissipation, current-dependent  | P <sub>vid</sub>  | W  | 0  |
| Static heat dissipation, non-current-dependent   | P <sub>vs</sub>   | W  | 0  |
| Heat dissipation capacity  | P <sub>diss</sub> | W  | 0  |
| Operating ambient temperature min.   |                   | °C | -25  |
| Operating ambient temperature max.   |                   | °C | 70   |
| IEC/EN 61439 design verification   |                   |    |  |
| 10.2 Strength of materials and parts   |                   |    |  |
| 10.2.2 Corrosion resistance  |                   |    | Meets the product standard's requirements.                         |
| 10.2.3.1 Verification of thermal stability of enclosures   |                   |    | Meets the product standard's requirements.                         |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat   |                   |    | Meets the product standard's requirements.                         |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects $\frac{1}{2} \left( \frac{1}{2} \right) = \frac{1}{2} \left( \frac{1}{2} \right) \left( $ |                   |    | Meets the product standard's requirements.                         |
| 10.2.4 Resistance to ultra-violet (UV) radiation   |                   |    | Meets the product standard's requirements.                         |
| 10.2.5 Lifting   |                   |    | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact   |                   |    | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions  |                   |    | Meets the product standard's requirements.                         |
| 10.3 Degree of protection of ASSEMBLIES  |                   |    | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances   |                   |    | Meets the product standard's requirements.                         |
| 10.5 Protection against electric shock   |                   |    | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components   |                   |    | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 Internal electrical circuits and connections  |                   |    | Is the panel builder's responsibility.                             |
| 10.8 Connections for external conductors   |                   |    | Is the panel builder's responsibility.                             |

| 10.9 Insulation properties                               |  |
|--|--|
| 10.9.2 Power-frequency electric strength                 | Is the panel builder's responsibility.   |
| 10.9.3 Impulse withstand voltage                         | Is the panel builder's responsibility.   |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility.   |
| 10.10 Temperature rise                                   | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating                               | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.12 Electromagnetic compatibility                      | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 Mechanical function                                | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |

### **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Auxiliary contact block (EC000041) Electric engineering, automation, process control engineering / Low-voltage switch technology / Component for low-voltage switching technology / Auxiliary switch block (ecl@ss10.0.1-27-37-13-02 [AKN342013]) Number of contacts as change-over contact 0 Number of contacts as normally open contact Number of contacts as normally closed contact 3 Number of fault-signal switches 0 6 Rated operation current le at AC-15, 230 V Α Type of electric connection Screw connection Model Top mounting Mounting method Floor fastening

### **Approvals**

Lamp holder

| - pp c. a.c.                |  |
|-----------------------------|--|
| Product Standards           | IEC/EN 60947-5; UL 508; CSA-C22.2 No. 14-05; CSA-C22.2 No. 94-91; CE marking |
| UL File No.                 | E340491  |
| UL Category Control No.     | NISD   |
| CSA File No.                | 012528_C_000   |
| CSA Class No.               | 3211-03  |
| North America Certification | UL listed, CSA certified   |

None

### **Assets (links)**

**Declaration of CE Conformity** 00003256

**Instruction Leaflets** 

IL04716005Z2018\_07