## **DATASHEET - EML30**



Terminal block, 4 x 4/0-500 MCM, 4 x 120-240 mm $^2$ , For use with: S801+, S811+, frame size V



Part no. EML30 Catalog No. 127667 Alternate Catalog EML30

No.

EL-Nummer 4137503

(Norway)

## **Delivery program**

Accessories		Terminal blocks
Ordering information		1 set required for each connection side.
For use with		S801+, S811+, frame size V
Terminal capacities	$\text{mm}^2$	4 x 4/0-500 MCM, 4 x 120-240 mm <sup>2</sup>
Instructions Tools with dimensions in inches required		

Design verification as per IEC/EN 61439

Design verification as per IEC/EN 61439		
Technical data for design verification		
Operating ambient temperature min.	°C	-30
Operating ambient temperature max.	°C	50
IEC/EN 61439 design verification		
10.2 Strength of materials and parts		
10.2.2 Corrosion resistance		Meets the product standard's requirements.
10.2.3.1 Verification of thermal stability of enclosures		Meets the product standard's requirements.
10.2.3.2 Verification of resistance of insulating materials to normal heat		Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects		Meets the product standard's requirements.
10.2.4 Resistance to ultra-violet (UV) radiation		Meets the product standard's requirements.
10.2.5 Lifting		Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 Mechanical impact		Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 Inscriptions		Meets the product standard's requirements.
10.3 Degree of protection of ASSEMBLIES		Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances		Meets the product standard's requirements.
10.5 Protection against electric shock		Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components		Does not apply, since the entire switchgear needs to be evaluated.
10.7 Internal electrical circuits and connections		Is the panel builder's responsibility.
10.8 Connections for external conductors		Is the panel builder's responsibility.
10.9 Insulation properties		
10.9.2 Power-frequency electric strength		Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage		Is the panel builder's responsibility.
10.9.4 Testing of enclosures made of insulating material		Is the panel builder's responsibility.
10.10 Temperature rise		The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 Short-circuit rating		Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 Electromagnetic compatibility		Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 Mechanical function		The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

## **Technical data ETIM 7.0**

Low-voltage industrial components (EG000017) / Connection vane/phase spreader (EC002019)

 $Electric \ engineering, \ automation, \ process \ control\ engineering\ /\ Low-voltage\ switch\ technology\ /\ Component\ for\ low-voltage\ switching\ technology\ /\ Connection\ vane\ /\ phase\ spreader\ (ecl@ss10.0.1-27-37-13-05\ [ACN990012])$ 

Suitable for number of poles 3

## **Approvals**

Product Standards	UL508, CSA C22.2 No. 65
UL File No.	E202571
UL Category Control No.	NMFT
CSA File No.	LR 353
CSA Class No.	6223-02
North America Certification	UL listed, CSA certified