

Noratel AS

P.O. 133

N-3301 HOKKSUND

Tel: +47 32 25 15 00

Fax: +47 32 25 15 50

firmapost@noratel.no



ISO 9001 Certified

Manufacturer:

Noratel AS – Norway

Address:

P.O. 133, N – 3301 Hokksund Norway

herewith declares that:

Type of equipment:

1-Phase; Isolating Transformers

<1000VAC at primary and <1000VAC at secondary or <1000VDC $\sqrt{2}$ at secondary

Type designation etc.:

**SU60X-XX, SU66X-XX, SU75X-XX, SU78X-XX, SU84X-XX, SU92X-XX, SU96X-XX,
SU105X-XX, SU108X-XX, SU120X-XX, SU130X-XX, SU135X-XX, SU150X-XX,
SU170X-XX, SU174X-XX, SU180X-XX, SU192X-XX, SU195X-XX, SU231X-XX**

Data:

10VA ... 5000VA

Class III, Ambient temp. 25/40/45°C, Cooling; AN, Frequency; 47-63Hz

IP00/IP2X/IP4X/IP5X, Insul.cl.; E/B

Mobility; stationary, With (...S) or without static screens

- *is in conformity with the provisions of the following EC directive(s), including the latest amendments, and with national legislation implementing this/these directives:*

- 1. Low Voltage Directive 2014/35/EU**
- 2. EMC Directive 2014/30/EU**

and that the following (parts/clauses of) harmonized standards have been applied:

- 1. EN 61558-1:2005+A1:2009 - General requirements**
EN 61558-2-4:2009, Particular requirements for Isolating transformers for general use.
- 2. Electromagnetic compatibility acc. to the EMC directive**
The transformer contains no components that generate or are sensitive to electromagnetic disturbances.

- *the following (parts/clauses of) national and/or international technical standards and specifications have been applied:*


- 1. DNV(Det Norske Veritas) rules for classifications of ships, Light Craft and Naval Surface Craft**
- 2. IEC 60092, Electrical installation in ships**

The date of  - marking: **01.01.1996**

Place: **Hokksund**

Date: **19.04.2016**

Signature:



Clarification:

Lam Quang Ho

Position:

Design Engineer