

Noratel AS

P.O. 133

N-3301 HOKKSUND

Tel: +47 32 25 15 00

Fax: +47 32 25 15 50

firmapost@noratel.no



ISO 9001 Certified

Manufacturer:

Noratel AS – Norway

Address:

P.O. 133, N – 3301 Hokksund Norway

herewith declares that:

Type of equipment:

**1-Phase; DC Power supplies “Safety Isolating Transformers”
<1000VAC at primary and <50VAC at secondary or <50VDC $\sqrt{2}$ at secondary**

Type designation etc.:

LFRC66B-XX, LFRC84B-XX, LFRC96B-XX, LFRC96BK-XX, LFRC96C-XX, LFRC96CK-XX

Data:

- **15W 100W • Ripple; max 5% RMS**
- **Class II • Ambient temp. 40°C • Cooling; AN • Frequency; 47-63Hz**
- **IP2X/IP4X/IP5X • Insul.cl.; B**
- **Mobility; stationary or portable • With pri. or sec. cable/plug or sockets**

- *is in conformity with the provisions of the following EC directive(s), including the latest amendments, and with national legislation implementing this/these directives:*

- 1. Low Voltage Directive 2014/35/EU**
- 2. EMC Directive 2014/30/EU**

and that the following (parts/clauses of) harmonized standards have been applied:

- 1. EN 61558-1:2005+A1:2009 - General requirements
EN 61558-2-6:2009, Particular requirements for Safety isolating transformers for general use.**
- 2. EN 55014:1993 (EN 55014-1:1997), EN 61000-3-2:1995, EN 61000-3-3:1995
EN 55104:1995 (EN 55014-2:1997), EN 50081-1:1992, EN 50082-2:1995
Electromagnetic compatibility acc. to the EMC directive**

- *the following (parts/clauses of) national and/or international technical standards and specifications have been applied:*

N/A

The date of  - marking: **01.01.1998**


Place: **Hokksund**

Date: **19.04.2016**

Signature:

Clarification:

Position:



Lam Quang Ho

Design Engineer